

The original and first copy of this report are to be filed with the

WATER WELL REPORT

RECEIVED

2 S/E-8ad

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

CLACK 03022

STATE OF OREGON (Please type or print)

FEB 5 1975

State Well No.

State Permit No.

STATE ENGINEER SALEM, OREGON

G-7095

Do not write above this line

(1) OWNER:

Name Lake Oswego Hunt Address P. O. Box 140, Lake Oswego, Or. 97034

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in item 12.

(3) TYPE OF WELL:

Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal [] Irrigation [X] Test Well [] Other []

CASING INSTALLED:

6" Diam. from 0 ft. to 82 ft. Gage 0.250 Threaded [] Welded [X]

PERFORATIONS:

Perforated? [] Yes [X] No.

Type of perforator used

Table with columns: Size of perforations, in. by, in., ft. to, ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No

Manufacturer's Name, Type, Model No., Diam., Slot size, Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [X] Yes [] No If yes, by whom? Yield: 150 gal./min. with 11 ft. drawdown after 8 hrs.

(9) CONSTRUCTION:

Well seal—Material used Bentonite Well sealed from land surface to 62 ft. Diameter of well bore to bottom of seal 10 in. Diameter of well bore below seal 6 in. Number of sacks of cement used in well seal sacks Number of sacks of bentonite used in well seal 4 sacks Brand name of bentonite National Number of pounds of bentonite per 100 gallons of water lbs./100 gals. Was a drive shoe used? [X] Yes [] No Plugs Size: location ft. Did any strata contain unusable water? [X] Yes [] No Type of water? SWAMP depth of strata 0-58 Method of sealing strata off Bentonite Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Clackamas Driller's well number 2-75 SE 1/4 NE 1/4 Section 8 T. 2S R. 1E W.M. Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 58 ft. Static level plus 4 ft. below land surface. Date 1/28/75 Artesian pressure 1 1/2 lbs. per square inch. Date 1/28/75

(12) WELL LOG:

Diameter of well below casing 6" Depth drilled 84 ft. Depth of completed well 84 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows: Silt, brown (0-49), Sand and rock chips (49-58), Broken rock and sand (58-84) Plus 4

Work started Jan. 10 1975 Completed Jan. 28 1975 Date well drilling machine moved off of well Jan. 28 1975

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Robert E. McConnell Date Feb. 3, 1975 (Drilling Machine Operator)

Drilling Machine Operator's License No. 398

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Steinman Bros. (Person, firm or corporation) (Type or print)

Address 14912 S.E. Kellogg Ave., Milwaukie, Or. 97222

[Signed] Robert E. McConnell (Water Well Contractor)

Contractor's License No. I Date Feb. 3, 1975

Hazel Rooke Executrix
Estate of Chas. G. Myers
4545 N.E. 29
Portland 11, Oregon

25/1-8F

Well log

Office of State Engineer:

In regards to the last well dug by my late father Chas. G Myers
License No. 144 I will try to give you the information you need
for your records.

Owner is James Hartfield Dogwood Drive, Lakegrove, Clackamas County
Oregon

Location- Northeast corner Lot No. 27 Pilkington

Use- Domestic

Type- Dug

Perforations- No

Screens- No

Construction- 3/4 inch gravel/packed. No seal

Water Level- ?

Well Test- ?

Well Log- Diameter 33 inches Depth 36 feet Material- Top soil
15 to 17 feet of blue clay. Bottom ? Completed on or about

July 2, 1959

RECEIVED
DEC 30 1959
STATE ENGINEER
OREGON

Hazel Rooke Ex.