

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED WATER WELL REPORT CLACK

CLACK 00304

State Well No. 11-25 cb

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date of well completion.

DEC 3 1 1969

STATE OF OREGON  
(Please type or print)

(Do not write above this line)

STATE ENGINEER  
SALEM, OREGON

State Permit No. G5116

(1) OWNER:

Name C.C. WARREN  
Address 2323 HARVESTER DRIVE MILWAUKEE ORE.

(11) LOCATION OF WELL:

County CLACK Driller's well number 5228  
NW 1/4 SW 1/4 Section 25 T. 15 R. 1E W.M.  
Bearing and distance from section or subdivision corner

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Cable  Dug   
Driven  Jetted  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

CASING INSTALLED:

8" Diam. from 0 ft. to 150 ft. Gage 277  
6" Diam. from 192 ft. to 201 ft. Gage 250  
6" Diam. from 221 ft. to 225 ft. Gage 250

PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used TORCH  
Size of perforations 3/8 in. by 4 in.  
384 perforations from 192 ft. to 201 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(7) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name JOHNSON  
Type STAINLESS Model No.  
Diam. 7 5/8 Slot size 100 Set from 211 ft. to 221 ft.  
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 40 ft. below land surface Date DEC 3 1969  
An pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level. PUMP, PIPES AND POWER  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: 250 gal./min. with 140 ft. drawdown after 8 hrs.

Baller test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water Was a chemical analysis made?  Yes  No

(10) CONSTRUCTION:

Well seal—Material used CEMENT GROUT  
Depth of seal 150 ft.  
Diameter of well bore to bottom of seal 10 in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Did any strata contain unusable water?  Yes  No  
Type of water? SURFACE depth of strata 31 FT  
Method of sealing strata off CASING AND GROUT  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.

(12) WELL LOG:

Diameter of well below casing 8  
Depth drilled 227 ft. Depth of completed well 227 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
TOP SOIL	0	9	
CEMENTED GRAVEL	9	12	
LOOSE GRAVEL	12	31	
SAND GRAVEL AND CLAY	31	75	
BLUE CLAY	75	85	
GREEN SANDY CLAY	85	97	
RED CLAY	97	112	
GREY CLAY	112	132	
GREEN CLAY AND GRAVEL	132	140	
SOFT BLACK ROCK	140	170	
DARK GREY BASALT	170	198	
RED BROKEN ROCK	198	225	
DARK GREY BASALT	225	227	

Work started MAY 7 1969 Completed DEC 1 1969  
Date well drilling machine moved off of well DEC 2 1969

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Charles M. [Signature] Date DEC 17 1969  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 674

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R.J. STRASSER DRILLING CO  
(Person, firm or corporation) (Type or print)

Address 810 SE SUNSET LANE PORTLAND ORE.

[Signed] Robert J. Strasser  
(Water Well Contractor)

Contractor's License No. 10 Date Dec 17 1969