

CLAC 00305

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print)

State Well No. 111-25

State Permit No.

(1) OWNER:

Name CITY OF MILWAUKIE Address MILWAUKIE, ORE.

(2) LOCATION OF WELL:

County CLACK Driller's well number 4147 Section 25 T. 15 R. 1E W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [X] Irrigation [] Test Well [] Other []

(5) TYPE OF WELL:

Rotary Cable [] Dug [] Driven [] Jetted [] Bored []

(6) CASING INSTALLED:

16" Diam. from 0 ft. to 285 ft. Gage 1312 12" Diam. from 276 ft. to 283 ft. Gage 330

(7) PERFORATIONS:

Perforated? [X] Yes [] No Type of perforator used STAR Size of perforations 3/8 in. by 1 1/4 in. 600 perforations from 170 ft. to 180 ft. 1800 perforations from 184 ft. to 214 ft. 1020 perforations from 255 ft. to 274 ft. 280 perforations from 315 ft. to 322 ft. 600 perforations from 355 ft. to 370 ft.

(8) SCREENS:

Well screen installed [] Yes [X] No Manufacturer's Name Type Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT GROUT Depth of seal 55 ft. Was a packer used? No Diameter of well bore to bottom of seal 20 in. Were any loose strata cemented off? [] Yes [X] No Depth Was a drive shoe used? [X] Yes [] No Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [X] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 101 ft. below land surface Date MAY 4 1963 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level. Was a pump test made? [X] Yes [] No If yes, by whom? R. STRASSER Yield: 750 gal./min. with 89 ft. drawdown after 8 hrs.

(12) WELL LOG:

Table with columns: MATERIAL, FROM, TO. Rows include: TOP SOIL, DRY SAND, CEMENTED GRAVEL, SANDY CLAY AND GRAVEL, STICKY CLAY AND GRAVEL, GRAVEL AND BOULDERS, SAND AND GRAVEL, COARSE SAND AND GRAVEL, GRAVEL FINE SAND, SANDY CLAY, SAND, GRAVEL AND CLAY, SAND AND GRAVEL, BLUE CLAY, CEMENTED GRAVEL, SAND AND GRAVEL, CEMENTED GRAVEL, SAND AND GRAVEL, BROWN CLAY, BLACK AND RED ROCK.

Work started FEB 7 19 63 Completed MAY 7 19 63 Date well drilling machine moved off of well MAY 7 19 63

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. NAME R. STRASSER DRILLING CO. Address 8110 SE SUNSET LANE PORT ORE Drilling Machine Operator's License No. 58 [Signed] Robert L. Strasser (Water Well Contractor) Contractor's License No. 10 Date MAY 18 1963