FREGEIVER CLAC 03052 3 WATER WELL REPORT

File Original and

2/1-120(1)

First Copy with the STATE ENGINEER, SALEM, OREGON STATE ENCINEATE OF OREGON State Permit No. __G1362 (1) OWNER: Drawdown is amount water level is lowered below static level (11) WELL TESTS: Name Fred Meyer Was a pump test made? Yes No If yes, by whom? Address 721 S. W. 4th Ave. gal./min. with 54 ft. drawdown after 10 hrs. Portland, Oregon 250 107 10 290 (2) LOCATION OF WELL: Bailer test gal./min. with ft. drawdown after County Clackamas Owner's number, if any-Artesian flow R. 1 E g.p.m. Date 14 NW 14 Section 12 T. 23 Temperature of water 55 5 Was a chemical analysis made?

Yes Bearing and distance from section or subdivision corner 2300 Ft. N and 80 Ft. W. from center 12 (12) WELL LOG: Diameter of well . inches. of Sec. 12 2 S 1 E Depth drilled 471 ft. Depth of completed well Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation. MATERIAL Topsoil and clay (3) TYPE OF WORK (check): 0 10 Boulders and clay New Well ₩ Reconditioning [Deepening | 10 Abandon 🗍 18 If abandonment, describe material and procedure in Item 11. Clay, gravel and boulders 18 35 Sand and clay 35 70 ROPOSED USE (check): (5) TYPE OF WELL: Broken rock, clay in crevices 119 70 Rotary Driven Domestic | Industrial | Municipal | Hard black basalt 119 154 Cable Jetted Irrigation [Test Well [Other Dug Bored Med. hard black basalt 154 160 Very hard grey basalt 160 214 (6) CASING INSTALLED: Threaded | Welded | Soft black rock 214 271 Porous black rock - some water 271 315 " Diam. from _____ ft. to ____ ft. Gage ____ Med. hard black basalt 315 351 " Diam. from _____ft. to _____ft. Gage ___ Very hard grey basalt 351 387 Soft black rock - water bearing 387 411 (7) PERFORATIONS: Perforated? | Yes XNo Med. hard black rock 411 438 Type of perforator used Soft-red rock 438 440 SIZE of perforations in. by Hard grey basalt 440 449 perforations from _____ ft. to _____ Black rock - seamy - water 449 471 ___ perforations from ____ ft. to ____ ft. perforations from _____ ft. to ____ ft. perforations from _____ft. to ____ (8) SCREENS: Well screen installed 🔲 Yes ដ No Manufacturer's Name Model No. Diam. Slot size ft. to ft. Slot size ____ Set from ____ ft, to ____ ft March 23 19 60 Completed Work started (9) CONSTRUCTION: (13) PUMP: Was well gravel packed?

Yes

No Size of gravel: Manufacturer's Name Gravel placed from _____ ft. to ____ ft. Was a surface seal provided? ₩ Yes □ No To what depth?130.... ft. Material used in seal-Well Driller's Statement: Did any strata contain unusable water? 🖺 Yes 📋 No This well was drilled under my jurisdiction and this report is Depth of strata 8 ft. to 40 f Type of water? true to the best of my knowledge and belief. cement grout Method of sealing strata off NAME R. J. STRASSER DRILLING CO. (Person, firm, or corporation) (Type or print) (10) WATER LEVELS: ft. below land surface Date June 30, Address 8110 S.E. Sunset Lane, Portland 6 Static level 178 Artesian pressure lbs. per square inch Date Driller's well number, Log Accepted by [Signed] [Signed Fleshing & M.C. Date 10/2] , 1860.

OKONESON License No. 10 Date August 15 , 1960