

NOTICE TO WATER WELL CONTRACTOR

The original and first of this report are to be filed with the

RECEIVED CLAC 03107 MAY 22 1969 STATE ENGINEER SALEM OREGON

WATER WELL REPORT

STATE OF OREGON

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

Please type or print (Do not write above this line)

State Well No. 2/1-16 bd

State Permit No.

(1) OWNER:

Name LAKE OSWEGOO HIGH SCHOOL Address 2455 SW COUNTRY CLUB ROAD LAKE OSWEGOO, ORE.

(2) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ] If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [X] Driven [ ] Cable [X] Jetted [ ] Dug [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [ ] Test Well [ ] Other [X]

CASING INSTALLED:

8" Diam. from 0 ft. to 119 ft. Gage 277

PERFORATIONS:

Perforated? [ ] Yes [X] No

Type of perforator used Size of perforations in. by in. perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [ ] Yes [X] No

Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 396 ft. below land surface Date MAY 5 1969 Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [X] Yes [ ] No If yes, by whom? STRASSER Yield: 195 gal./min. with 100 ft. drawdown after 16 hrs.

(10) CONSTRUCTION:

Well seal—Material used CEMENT GROUT Depth of seal 23-29 AND 100-110 ft. Diameter of well bore to bottom of seal 10 3/4 in.

(11) LOCATION OF WELL:

County CLACK Driller's well number 5310 SE 1/4 NW 1/4 Section 16 T. 25 R. 1E W.M.

(12) WELL LOG:

Diameter of well below casing 8" Depth drilled 907 ft. Depth of completed well 907 ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Content: SEE ATTACHED SHEET

Work started MAR 6 1969 Completed MAY 8 1969 Date well drilling machine moved off of well MAY 8 1969

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] M. C. Smith Date 5/10, 1969 (Drilling Machine Operator)

Drilling Machine Operator's License No. 175

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. L. STRASSER DRILLING CO (Person, firm or corporation) (Type or print) Address 8110 SE SUNSET LAKE PORTLAND ORE. [Signed] Robert L. Strasser (Water Well Contractor) Contractor's License No. 10 Date MAY 20, 1969

*R. J. Strasser Drilling Co.*8110 S. E. Sunset Lane  
Portland, Oregon 97206

May 19, 1969

Log of well #1 for Lake Oswego High School

**RECEIVED**  
MAY 22 1969  
STATE ENGINEER  
SALEM, OREGON

top soil	0 - 6
yellow clay	6 - 44
sandstone	44 - 98
brown basalt	98 - 120
medium hard grey basalt	120 - 140
brown sandstone	140 - 158
medium hard grey basalt	158 - 166
brown lava	166 - 182
medium hard grey basalt	182 - 214
conglomerate	214 - 232
brown basalt	232 - 280
medium hard grey basalt	280 - 290
red lava	290 - 294
brown lava	294 - 310
grey basalt	310 - 348
broken brown basalt	348 - 390
medium hard grey basalt	390 - 428
broken brown basalt	428 - 444
medium hard grey basalt	444 - 480
hard grey basalt	480 - 552
broken brown basalt	552 - 583
medium hard grey basalt	583 - 642
broken brown basalt	642 - 655
medium hard grey basalt	655 - 670
broken brown basalt	670 - 747
blue clay and rock	747 - 771
green and black rock	771 - 780
medium hard grey basalt	780 - 793
hard black basalt	793 - 803
medium hard grey basalt	803 - 822
grey mudstone	822 - 869
black rock and clay	869 - 882
black basalt	882 - 907