

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report are to be filed with the  
STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date of well completion.

CLAC  
03171

RECEIVED  
APR 14 1967  
STATE ENGINEER  
OREGON

WATER WELL REPORT  
STATE ENGINEER OREGON  
State Well No. 2/1-20 R  
State Permit No.

(1) OWNER:

Name STAFFORD SCHOOL  
Address WEST LINN SCHOOL DIST. #3  
CLACKAMAS COUNTY, OREGON

(2) LOCATION OF WELL:

County CLACK. Driller's well number 4242  
SE 1/4 SE 1/4 Section 20 T. 25 R. 1E W.M.  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal  Irrigation  Test Well  Other   
Rotary  Cable  Dug  Driven  Jetted  Bored

(6) CASING INSTALLED:

8" Diam. from 0 ft. to 44 ft. Gage 2.77  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used  
Size of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(8) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name  
Type Model No.  
Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION: 8 IN PIPE CEMENTED INTO ROCK FROM 430 TO 444

Well seal—Material used in seal BENTONITE  
Depth of seal 52 ft. Was a packer used? No  
Diameter of well bore to bottom of seal 12 in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off

(10) WATER LEVELS:

Static level 55 ft. below land surface Date 3/10/67  
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? STRASSER  
Yield: 130 gal./min. with 250 ft. drawdown after 8 hrs.  
" 94 " 185 " 9 "  
" 67 " 151 " 10 "  
" 47 " 117 " 12 "  
Bailer test 45 gal./min. with 75 ft. drawdown after 1 hrs.  
Artesian flow g.p.m. Date  
Temperature of water 59° Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing 8 AND 6  
Depth drilled 605 ft. Depth of completed well 605 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
BROWN SANDY CLAY	0	57
BROWN SAND	57	64
BLUE CLAY	64	85
BROWN SAND	85	90
BROWN SAND, SOME GRAVEL	90	92
BLUE CLAY	92	136
BLUE SHALE	136	185
BLUE CLAY	185	220
SOFT BLUE SHALE	220	275
BLUE CLAY	275	301
ROCK	301	303
BROWN CLAY	303	342
RED CLAY	342	405
WEATHERED LAVA AND CLAY	405	426
BROWN CLAY	426	430
WEATHERED LAVA	430	444
BLACK BASALT	444	470
HARD BLACK BASALT	470	475
MED HARD BLACK BASALT	475	520
SOFT BASALT	520	524
MED HARD BLACK BASALT	524	572
SOFT BROWN BASALT	572	580
MED HARD BLACK BASALT	580	605

Work started 12/27 1966 Completed 3/10 1967  
Date well drilling machine moved off of well 3/10 1967

(13) PUMP:

Manufacturer's Name  
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R.J. STRASSER DRILLING CO  
(Person, firm or corporation) (Type or print)

Address 2110 SE SUNSET LAKE PORTLAND ORE

Drilling Machine Operator's License No. 329

[Signed] Robert L. Strasser  
(Water Well Contractor)

Contractor's License No. 10 Date MAR 21 1967