

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the
STATE ENGINEER, SALEM 10, OREGON
within 30 days from the date
of well completion.

RECEIVED
AUG 28 1963
STATE ENGINEER
SALEM, OREGON

CLAC. 00320

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Well No. 111-36c
State Permit No. G2808

(1) OWNER:
Name WILLIAM C WILHELM
Address 6637 SE MILWAUKIE AVE
PORTLAND ORE

(2) LOCATION OF WELL:
County CLACK Driller's well number 4154
Bearing and distance from section or subdivision corner
140'S AND 1740' W FROM NE
CORNER OF KARLEN'S SECOND
ADDITION

(3) TYPE OF WORK (check):
Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:
8" Diam. from 0 ft. to 80 ft. Gage .279
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:
Type of perforator used STAR
Size of perforations 3/8 in. by 1 1/4 in.
360 perforations from 56 ft. to 68 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed Yes No
Manufacturer's Name _____ Model No. _____
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal CEMENT GROUT
Depth of seal 21 ft. Was a packer used? NO
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:
Static level 32 ft. below land surface Date 8/7/63
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? R.J.S
Yield: 117 gal./min. with 10 ft. drawdown after 8 hrs.
" 150 " 13 " " " "
" 242 " 22 " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 54 Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing _____
Depth drilled 80 ft. Depth of completed well 80 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	4
GRAVEL BOULDERS AND CLAY	4	39
CEMENTED GRAVEL	39	49
SAND AND GRAVEL	49	54
WATER BEARING SAND AND GRAVEL	54	68
SAND, GRAVEL AND CLAY	68	80

Work started JULY 23, 1963 Completed AUG 9 1963
Date well drilling machine moved off of well AUG 9 1963

(13) PUMP:
Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME R.J. STRASSER DRILLING CO
(Person, firm or corporation) (Type or print)
Address 8110 SE SUNSET LANE PORT. ORE
Drilling Machine Operator's License No. 58
[Signed] Robert L. Strasser
(Water Well Contractor)
Contractor's License No. 10 Date AUG 14, 1963