

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print)

STATE ENGINEER

SALEM, OREGON

RECEIVED

APR 10 1974

State Well No. 25/1E-27

State Permit No.

CLAC 03462

ba

(1) OWNER:

Name REGENT INVESTMENT CO Address 2611 S.W. 30 AVE PORTLAND, ORE

(2) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ] If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [X] Driven [ ] Cable [ ] Jetted [ ] Dug [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [ ] Test Well [ ] Other [X]

(5) CASING INSTALLED:

8" Diam. from +1 ft. to 30 ft. Gage 377

(6) PERFORATIONS:

Type of perforator used Size of perforations in. by in. perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [ ] Yes [X] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [X] Yes [ ] No If yes, by whom? STRASSER Yield: 260 gal./min. with 113 ft. drawdown after 17 hrs.

(9) CONSTRUCTION:

Well seal-Material used No. 8 MESH BENTONITE Well sealed from land surface to 28 ft. Diameter of well bore to bottom of seal 10 in.

(10) LOCATION OF WELL:

County CLACK, Driller's well number 5472 NE 1/4 NN 1/4 Section 27 T. 25 R. 1E W.M. Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 294 ft. Static level 318 ft. below land surface. Date 4/1/74 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8 Depth drilled 638 ft. Depth of completed well 638 ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Content: SEE ATTACHED SHEET

Work started FEB 5 1974 Completed APR 4 1974 Date well drilling machine moved off of well APR 4 1974

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief. [Signed] Edward Schmitz Date APR 5, 1974

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Name R.J. STRASSER DRILLING CO Address 8110 SE SUSSEX LAKE PORTLAND ORE [Signed] Robert J. Strasser Date APR 5, 1974

RECEIVED

APR 10 1974

STATE ENGINEER  
SALEM, OREGON

# R. J. Strasser Drilling Co.

8110 S. E. Sunset Lane  
Portland, Oregon 97206

April 8, 1974

## Log of test well for Regent Investment Co. Oswego Greens

top soil	0 - 4
broken brown basalt	4 - 18
black basalt	18 - 41
soft brown basalt	41 - 90
medium hard black basalt	90 - 98
brown basalt	98 - 116
black basalt	116 - 143
brown basalt	143 - 170
black basalt	170 - 225
hard grey basalt	225 - 261
brown basalt	261 - 281
black basalt	281 - 294
broken black basalt	294 - 300
hard grey basalt	300 - 354
broken grey basalt	354 - 358
black basalt	358 - 375
brown basalt	375 - 389
hard grey basalt	389 - 435
broken grey basalt	435 - 462
black basalt	462 - 498
broken, brown basalt	498 - 524
medium hard black basalt	524 - 534
porous black basalt	534 - 541
hard grey basalt	541 - 628
broken black basalt	628 - 633
hard black basalt	633 - 638