

NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97300
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

Do not write above this line

CLAC

03508

State Well No. 2/1-28dc

State Permit No.

STATE ENGINEER

(1) OWNER:

SALEM, OREGON

Name Arthur EggerAddress RT 1, Box 2864 West Linn, Oregon

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED:

Threaded ☐ Welded ☒

" Diam. from 0 ft. to 49 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? ☐ Yes ☒ No.

Type of perforator used

Size of perforations	in.	by	in.
perforations from	ft.	to	ft.
perforations from	ft.	to	ft.
perforations from	ft.	to	ft.
perforations from	ft.	to	ft.
perforations from	ft.	to	ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 66 ft. below land surface Date 1-26-70

Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom? Operator

Yield: 18 gal./min. with 29 ft. drawdown after 2 hrs.

" " " "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water 51° Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:

Well seal—Material used Bentonite & casing

Depth of seal 0 to 45 ft.

Diameter of well bore to bottom of seal 9 in.

Were any loose strata cemented off? ☐ Yes ☒ No DepthWas a drive shoe used? ☐ Yes ☒ NoDid any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Clackamas Driller's well number 156

SW 1/4 SE 1/4 Section 28 T.2S R. 1E W.M.

Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 95 ft. Depth of completed well 95 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Brown Soil	0	2	
Brown Clay	2	10	
Fine Gray Sand	10	45	
Soft Gray Basalt	45	88	
Gray Brown Porous Basalt (limestone)	88	92	66
Soft Gray Basalt	92	95	

Work started 1-26 1970 Completed 1-26 1970

Date well drilling machine moved off of well 1-26 1970

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Raymond A. Borchers Date 1-26, 1970
(Drilling Machine Operator)

Drilling Machine Operator's License No. 305

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME B & S Drilling Co.
(Person, firm or corporation) (Type or print)

Address RT 3, Box 271A Sherwood Ore.

[Signed] Raymond A. Borchers
(Water Well Contractor)

Contractor's License No. 404 Date 1-26, 1970

(USE ADDITIONAL SHEETS IF NECESSARY)