## STATE OF OREGON

RECEIVED CLAC 03605

ř		1
	2-1	15-20/2
	X51	1E-3020
	- 1	

WATER WELL REPORT (as required by ORS 537.765)

FEB 2 1 1986,

WATER RESOURCES DEPA GALEM, GREGUIT

1) OWNER: Owner's Well Number:	(9) LOCATION OF WELL by legal description:
Name William Ososke Address 21366 S.W. Martinazzi	County Clack Latitude ' Longitude ' " Township 2 South Nors, Range 1 East E or W, WM.
City Tualatin State Oregon Zip97062	Township 2 50 to 511 N or S, Range 1 11 to 5 to E or W, WM.  Section 30 SE 4 SW 4
2) TYPE OF WORK:	Section
New Well Deepen Recondition Abandon	Street Address of Well (** ********************************
3) DRILL METHOD:	Rd., Tualatin, Oregon 97062
Rotary Air - Rotary Mud Cable Other	(10) STATIC WATER LEVEL:
	179 ft. below land surface. Date 2-17-86
	Artesian pressurelb. per square inch. Date
(4) PROPOSED USE:	/11\ WETT TOO.
Domestic Community Industrial Irrigation	
Thermal Injection Other	Material From To WB? SWL
BORE HOLE CONSTRUCTION:  Depth of Completed Well 318 218 ft.	Clay brown 5 0 7
Special Standards date of approval	Clay brown 5 0 7
HOLE SEAL Amount	Basalt weathered 7 19
Diameter From To Material From To sacks or pounds	r .
TO O ZO CHII, O ZO O SECENS	Basalt grey 19 29
Ε	
	Basalt grey & brown 29 125
How was seal placed? Method	Tr 74 0 44 127   121
Other	Basalt grey fractured125   131
Backfill placed from ft. to ft. Material	Basalt grey & brown 131 xxxx
Gravel placed fromft. toft. Size of gravel	Dapato atoy a District
(6) CASING/LINER:	Basalt black 184 247
Diameter From To Gauge Steel Plastic Welded Threaded Casing: 6" +1 27 250 🖾 🗆	<u> </u>
	Basalt grey & brown 247 271 X
	D1
	Basalt black 271 277
iner: 4" +1 318 160# □ □ □ □	Basalt grey 277 300
	Dabato groj
inal location of shoe(s)	Basalt grey crevised 300 321 X 179
PERFORATIONS/SCREENS:	
Perforations Method Saw	Basalt grey 321 323
Screens TypeMaterial Slot Tele/pipe	
From To size Number Diameter size Casing Liner	100
42 262 1/8 60 D	
300 316 1/8 150	
	Date started 2-11-86 Completed 2-17-86
(8) WELL TESTS: Minimum testing time is 1 hour	(unbonded) Water Well Constructor Certification:
□ Pump □ Bailer □ Artesian	I constructed this well in compliance with Oregon well construction
Yield gal/min Pumping level Drill stem at Time	standards. Materials used and information reported above are true to my best knowledge and belief.
23 220 ¼ hr	Ü
37 1 320 1 hr	Signed Date
	(bonded) Water Well Constructor Certification:
	I accept responsibility for construction of this well and its compliance
Pemperature of water Depth Artesian Flow Found  Vas a water analysis done?	with all Oregon water well standards. This report is true to the best of my knowledge and belief.
Did any strata contain water not suitable for intended use? Too little	10 TI 1000
Salty Muddy Odor Colored Other	Signed Date 18 Feb 1986
Depth of strata:	Company SKYLES DRILLING, INC. Job No. 0586