

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

CLACKAMAS WATER WELL REPORT
STATE OF OREGON
 03684 JUN-21 1977
 WATER RESOURCES DEPT.

State Well No. 25/1E-31

State Permit No. _____

(1) OWNER:

Name Stafford Baptist Church
 Address Wilsonville, Oregon

LOCATION OF WELL:

County Clackamas Driller's well number
 1/4 1/4 Section 3/2 T. 25 R. 1E W.M.
 Bearing and distance from section or subdivision corner

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

(4) PROPOSED USE (check):

Rotary Cable Dug Driven Jetted Bored Domestic Industrial Municipal Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
 " Diam. from _____ ft. to _____ ft. Gage
 " Diam. from _____ ft. to _____ ft. Gage
 " Diam. from _____ ft. to _____ ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____

Size of perforations _____ in. by _____ in.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
 Type _____ Model No. _____
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
 d: _____ gal./min. with _____ ft. drawdown after _____ hrs.
 " _____ " _____ " _____ "
 " _____ " _____ " _____ "
 Bailer test 15 gal./min. with 60 ft. drawdown after 1 hrs.
 Artesian flow _____ g.p.m.
 Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used _____
 Well sealed from land surface to _____ ft.
 Diameter of well bore to bottom of seal _____ in.
 Diameter of well bore below seal _____ in.
 Number of sacks of cement used in well seal _____ sacks
 Number of sacks of bentonite used in well seal _____ sacks
 Brand name of bentonite _____
 Number of pounds of bentonite per 100 gallons of water _____ lbs./100 gals.
 Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.

(11) WATER LEVEL: Completed well.

Depth at which water was first found 240 ft.
 Static level 190 ft. below land surface. Date 3/29/77
 Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 279 ft. Depth of completed well 279 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Basalt, black, scoriaceous	216	254	
Basalt, black & brown, scoriaceous	254	268	
Basalt, black, scoriaceous	268	279	

Work started 3/29 1977 Completed 3/29 1977
 Date well drilling machine moved off of well 3/29 1977

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Steven Shelly Date 2/29, 1977
 (Drilling Machine Operator)

Drilling Machine Operator's License No. 1096

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name D.V. Wyland & Co., Inc.
 (Person, firm or corporation) (Type or print)

Address 734 8th Street, Lake Oswego, Or

[Signed] Daniel V. Wyland
 (Water Well Contractor)

Contractor's License No. 554 Date 3/29, 1977