

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
 NOV 1 1968
STATE ENGINEER
SALEM OREGON

CLACK

00387

1/2-33 P

STATE OF OREGON

(Please type or print)

Do not write above this line

State Well No.

State Permit No.

(1) OWNER:

Name MILWAUKIE HIGH SCHOOL DIST CH
 Address 2202 SE WILLARD MILWAUKIE, ORE

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dig Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
 10" Diam. from 0 ft. to 409 ft. Gage 279
 9 1/4" Diam. from 404 ft. to 410 ft. Gage 250
 " Diam. from " ft. to " ft. Gage "

PERFORATIONS:

Perforated? Yes No.

Type of perforator used

Size of perforations in. by in.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name EDWARD E. JOHNSON, INC.
 Type STAINLESS STEEL Model No. _____
 Diam. 10 Slot size 60 Set from 410 ft. to 431 ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

level 136 ft. below land surface Date 10/10/68

Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? STRASSER
 1: 525 gal./min. with 34 ft. drawdown after 23 hrs.
400 " " 17 " " 23 1/2
 " 310 " " 10 " " 24 "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water 56° Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used CEMENT GROUT
 Depth of seal 50 FT ft.
 Diameter of well bore to bottom of seal 12 in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Did any strata contain unusable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County CLACK Driller's well number 4287
SE 1/4 SW 1/4 Section 33 T. 15 R. 2 E W.M.
 Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing

Depth drilled 435 ft. Depth of completed well 431 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
CLAY	0	32	
BLACK ROCK	32	73	
SOFT BROWN ROCK	73	96	
CONGLOMERATE	96	115	
SAND, GRAVEL AND CLAY	115	140	
CEMENTED GRAVEL	140	182	
GRAVEL SOME CLAY	182	197	
LOOSE GRAVEL	197	255	
SAND AND GRAVEL	255	297	
HARD BLUE CLAY	297	300	
GREY CLAY	300	330	
BLUE STICKY CLAY	330	360	
GREY CLAY	360	397	
SHALE	397	405	
BLACK SAND AND SMALL GRAVEL	405	435	

Work started SEPT 4 1968 Completed OCT 15 1968

Date well drilling machine moved off of well OCT 15 1968

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Don W Johnson Date 29, 1968
 (Drilling Machine Operator)

Drilling Machine Operator's License No. 57

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. STRASSER DRILLING CO
 (Person, firm or corporation) (Type or print)

Address 8110 SE SUNSET LANE PORTLAND, ORE

[Signed] Robert L Strasser
 (Water Well Contractor)

Contractor's License No. 10 Date OCT 29 1968