

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED FEB 2 1968

STATE ENGINEER WATER WELL REPORT

RECEIVED CLAC

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE OF OREGON

FEB 6 1968

State Well No.

2/2-10 F

STATE ENGINEER SALEM OREGON 97301

(Please type or print) Do not write above this line

STATE ENGINEER SALEM, OREGON

State Permit No.

4029  
CLAC

6-4780

(1) OWNER:

Name Oak Acres Mobile Homes Park Inc.  
Address RT 2, By 66 Clackamas Oregon

(11) LOCATION OF WELL:

County Clackamas Driller's well number  
Bearing and distance from section or subdivision corner  
160' W. and 30' South of NE Cor. of tract described in attached description

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(12) WELL LOG: Diameter of well below casing 12"

Depth drilled 312 ft. Depth of completed well 312 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
<u>Cemented gravel topsoil</u>	<u>6'</u>	<u>45'</u>	<u>7 1/2'</u>
<u>sand</u>	<u>45'</u>	<u>47'</u>	
<u>blue clay</u>	<u>47'</u>	<u>67'</u>	
<u>gravel (hard)</u>	<u>67'</u>	<u>68'</u>	
<u>blue clay</u>	<u>68'</u>	<u>76'</u>	
<u>gravel</u>	<u>76'</u>	<u>77'</u>	
<u>sticky blue clay</u>	<u>77'</u>	<u>80'</u>	
<u>gray sand &amp; gravel</u>	<u>80'</u>	<u>115'</u>	<u>23'</u>
<u>green shale</u>	<u>115'</u>	<u>127'</u>	
<u>gray sand &amp; gravel</u>	<u>127'</u>	<u>140'</u>	
<u>small gray medium grain fine sand</u>	<u>140'</u>	<u>146'</u>	
<u>fine sand</u>	<u>146'</u>	<u>148'</u>	
<u>hard gravel cobbles rock</u>	<u>148'</u>	<u>189'</u>	
<u>sticky clay</u>	<u>189'</u>	<u>190'</u>	
<u>loose sand &amp; gravel</u>	<u>190'</u>	<u>199'</u>	<u>41'</u>
<u>hard sandy clay</u>	<u>199'</u>	<u>201'</u>	
<u>loose sand &amp; gravel</u>	<u>201'</u>	<u>225'</u>	
<u>sticky blue shale</u>	<u>225'</u>	<u>230'</u>	
<u>shale &amp; gravel streaks</u>	<u>230'</u>	<u>245'</u>	
<u>sand &amp; shale streaks</u>	<u>245'</u>	<u>296'</u>	
<u>shale</u>	<u>296'</u>	<u>312'</u>	

CASING INSTALLED:

Threaded  Welded   
10" Diam. from 0 ft. to 300' 8" ft. Gage 250  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

PERFORATIONS:

Perforated?  Yes  No.

Type of perforator used Mechanical type cutter  
Size of perforations 1 1/4" in. by 1/8" in.  
150 perforations from 80' ft. to 130' ft.  
405 perforations from 160' ft. to 295' ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(7) SCREENS:

Well screen installed?  Yes  No.

Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WATER LEVEL: Completed well.

Static level 43' ft. below land surface Date Jan 31, 68  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No owner  
250 gal./min. with 60 ft. drawdown after 48 hrs.  
Static level before test 25'  
after test stands at 43'  
Bailer test none gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
Temperature of water \_\_\_\_\_ Was a chemical analysis made?  Yes  No

(10) CONSTRUCTION:

Well seal—Material used Pentonite & cement  
Depth of seal 19' ft.  
Diameter of well bore to bottom of seal 12" in.  
Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
Was a drive shoe used?  Yes  No  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Work started Aug 24 1967 Completed Oct. 31 1967

Date well drilling machine moved off of well Nov 1 1967

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] D. E. Jannsen Date Nov 3, 1967  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 237

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME D. E. Jannsen (Type or print)  
(Person, firm or corporation)

Address By 38 Clackamas Oregon 97015

[Signed] D. E. Jannsen (Water Well Contractor)

Contractor's License No. 3 Date Nov. 3, 1967