water resources department, P 2 4 1979

STATE OF CONTROL OF PROPERTY RESOURCES DEPONDS Write above this line) 04042 state Fermit No. SALEM. OREGON (1) OWNER: (10) LOCAMON OF WELL: Name River Bend Mobile Home Park LTD. County Clackamas Driller's well number D-237-79 Address 1512 S.W. 18th Ave. 14 SE 14 Section 11 т. 2S r. Portland, Oregon Bearing and distance from section or subdivision corner (2) TYPE OF WORK (check): New Well Deepening [7] Reconditioning [Abandon | If abandonment, describe material and procedure in Item 12. (11) WATER LEVEL: Completed well. (3) TYPE OF WELL: (4) PROPOSED USE (check): Depth at which water was first found Driven 🛘 Domestic ☐ Industrial ☐ Municipal 1 110 Static level Jetted 🛚 ft. below land surface. Date 9-12-79 Bored [Irrigation | Test Well | Other Artesian pressure lbs. per square inch. Date CASING INSTALLED: ASING INSTALLED: Threaded
Welded
Threaded
Gage • 250 (12) WELL LOG: Diameter of well below casing Depth drilled 800 ft. Depth of completed well" Diam, from ... __ft_ to ___ ... ft. Gage Formation: Describe color, texture, grain size and structure of materials; ..." Diam. from .. and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in PERFORATIONS: position of Static Water Level and indicate principal water-bearing strata. Perforated? Tyes Nino. Type of perforator used MATERIAL Size of perforations in, by topsoil boulders perforations from ft. to 45 boulders & clay brown perforations from 45 67 sandstone brown soft perforations from 83 clay gray sandy 83 188 (7) SCREENS: Well screen installed? | Yes | No sandstone black water bear 188197 Manufacturer's Name claystone & sandstone da **v 1**97 215 sandstone black W.B. 215 225 Diam. Slot size Set from ft. to sand brown fine 225 232 Diam. Slot size Set from sandstone & claystone gray232 370 sand gray find W.B. (8) WELL TESTS: Drawdown is amount water level is lowered below static level 370 426 clay blue sticky 426 498 a pump test made? MYes I No If yes, by whom? Aqua Pump sand gray fine 498 547 Yield: 200 gal./min. with 85 ft. drawdown after 24 hrs. clay gray sandy 547 556 sand gray W.B. & seams of sand 709 sandstone gray fine W.B. 709 788 r test gal./min. with ft. drawdown after <u>clay gray</u> 788 | 800 esian flow g.p.m. sand black water bearing 800 110 marature of water Depth artesian flow encountered Work started July 28 1979 Completed 9-9 1979 (9) CONSTRUCTION: Date well drilling machine moved off of well 1979 cement Well seal-Material used Drilling Machine Operator's Certification: This well was constructed under my direct supervision. Materials used and information reported above are true to my Well sealed from land surface to best knowledge, and belief Diameter of well bore below seal 8 in. Number of sacks of cement used in well seal ... How was cement grout placed? pressure grouted Drilling Machine Operator's License No. 1169 Water Well Contractor's Certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Was a drive shoe used? Yes 🗌 No Plugs Size: location ft. Name S & M DRILLING & SUPPLY, INC.
(Person, firm or corporation) (Type or print) Did any strata contain unusable water?

Yes X No Address 399 SE WALNUT ST CANBY, OR. 97013 Type of water? depth of strata Method of sealing strata off Was well gravel packed? ☐ Yes XXNo Size of gravel: Gravel placed from ft. to Contractor's License No. 497 Date 9-14-(USE ADDITIONAL SHEETS IN NECESSARY)

NOTICE TO WATER WELL CONTRAC

The original and first copy of this Pool E WATER WELL REPORT, are to be filed with the