ORIGINAL
File Original and Duplicate with the STATE ENGINEER, SALEM, OREGON

CLAC

RECEIVED
AUG 19 1958
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON

CLAC 04048

State Well No. 2/2-11 L (11)

State Permit No. .....

(1) OWNER:

Name Roy E. Wright

Address Route 1 Box 90

Clackamas, Oregon

(2) LOCATION OF WELL:

County Clackamas Owner's number, if any—

SE ¼ SW ¼ Section 11 T. 2S R. 2E W.M.

Bearing and distance from section or subdivision corner

G1216

(3) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐

Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary ☐ Driven ☐

Cable ☒ Jetted ☐

Dug ☐ Bored ☐

(6) CASING INSTALLED:

Threaded ☐ Welded ☒

6 " Diam. from 0 ft. to 88 ft. Gage .250

5 " Diam. from 88 ft. to 130 ft. Gage 3/16" liner

" Diam. from ..... ft. to ..... ft. Gage .....

(7) PERFORATIONS:

Perforated? ☒ Yes ☐ No

Type of perforator used Slotted with cuttung torch

SIZE of perforations 1/8 in. by 8 in.

10 perforations from 95 ft. to 100 ft.

20 perforations from 115 ft. to 130 ft.

..... perforations from ..... ft. to ..... ft.

..... perforations from ..... ft. to ..... ft.

..... perforations from ..... ft. to ..... ft.

(8) SCREENS:

Well screen installed ☐ Yes ☒ No

Manufacturer's Name .....

Type ..... Model No. .....

Diam. ..... Slot size ..... Set from ..... ft. to ..... ft.

..... Slot size ..... Set from ..... ft. to ..... ft.

(9) CONSTRUCTION:

Well gravel packed? ☐ Yes ☒ No Size of gravel: .....

Gravel placed from ..... ft. to ..... ft.

Was a surface seal provided? ☐ Yes ☐ No To what depth? ..... ft.

Material used in seal—

Did any strata contain unusable water? ☒ Yes ☐ No

Type of water? Excessive sand Depth of strata 76' to 79'

Method of sealing strata off Cased out

(10) WATER LEVELS:

Static level 6½ ft. below land surface Date 8/12/58

Artesian pressure ..... lbs. per square inch Date .....

Log Accepted by:

[Signed] R. E. Wright (Owner) Date ....., 19.....

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: ..... gal./min. with ..... ft. drawdown after ..... hrs.

" " " "

" " " "

Bailer test 10 gal./min. with 10 ft. drawdown after 2 hrs.

Artesian flow ..... g.p.m. Date .....

Temperature of water 51 Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG:

Diameter of well 6 inches.

Depth drilled 130 ft. Depth of completed well 130 ft.

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Top soil	0	3
Cement gravel	3	32
Cement gravel and boulders	32	47
Yellow clay	47	58
Blue clay	58	63
Grey clay	63	76
Black sand (water)	76	79
Grey clay	79	81
Brown sandy clay	81	90
Blue sticky clay	90	97
Blue packed sand (10 gpm)	97	103
Grey clay	103	127
Course sand and gravel (water)	127	130

Work started August 1958. Completed August 1958

(13) PUMP:

Manufacturer's Name .....

Type: ..... H.P. .....

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Steinman Bros. (Person, firm, or corporation) (Type or print)

Address 15112 S.E. McLoughlin-Milwaukie, Ore.

Driller's well number 36-58

[Signed] Steinman Bros. by Bob McConnell (Well Driller)

License No. 1 Date 8/13/58, 19.....

(USE ADDITIONAL SHEETS IF NECESSARY)