NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the AUG 5 1970 STATE OF STATE ENGINEER, SALEM, OREGON 97810	OREGON UG 1 4 1970 Thate Well by) 2/2-18F
state engineer, salem, oregon 97310 engineer type within 30 days from the dastate engineer type of well completion.	ove the line NGINE State Permit	No2438 C4202
(1) OWNER:	(10) LOCATION OF WELL:	1.18
Name MILWAUKIE HIGH SCHOOL DISTUHS	County CLACE, Driller's well	number 4/19
Address 2202 WILLARD MILWAUKIE ORE,	14 14 Section /8 T. 2.	S R. 3 E W.M.
MILWAUKIE ORE,	Bearing and distance from section or subdiv	ision corner
(2) TYPE OF WORK (check):		
New Well ☐ Deepening ★ Reconditioning ☐ Abandon ☐ If abandonment, describe material and procedure in Item 12.		
	(11) WATER LEVEL: Completed	well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found ft.	
Rotary Driven Domestic Dindustrial Municipal Domestic Municipal Domestic Dindustrial	Static level 136 ft. below land	d surface. Date 7/11/70
Dug	Artesian pressure lbs. per squ	ıare inch. Date
CASING INSTALLED: Threaded Welded	(12) WELL LOG: Diameter of well	I below casing6
"Diam. from	Depth drilled /3/ ft. Depth of con	apleted well 983 ft.
"Diam. fromft. toft. Gage	Formation: Describe color, texture, grain siz	
" Diam. from	and show thickness and nature of each stra	tum and aquifer penetrated,
DEDECO A MICAYC.	with at least one entry for each change of form position of Static Water Level and indicate p	
PERFORATIONS: Perforated? Yes No.		
Type of perforator used	MATERIAL	From To SWL
Size of perforations in. by in.	BROKEN BLACK KOCK	852 865
perforations from ft. to ft.	BLACK POROUS ROCK	865 878
perforations from	MED. HARD BLACK KOCK	£ 870 902
perforations from ft. to ft.	HARD BLACK ROCK	902-964
	BLACK ROCK WITH	
(7) SCREENS: Well screen installed? Yes No	SEAMS OF SEDIMENT	164 983
Manufacturer's Name		
Type Model No		
Diam. Slot size Set from ft. to ft.		
Diam. Slot size Set from ft. to ft.		
(8) WELL TESTS: Drawdown is amount water level is lowered below static level		
Was a pump test made? X Yes \(\subseteq \text{No If yes, by whom? KELLER} \)	,	
Yield: 190 gal./min. with 240 ft. drawdown after 9 hrs.		
" " "		
		·
" " " " " " " " " " " " " " " " " " "		
Bailer test gal./min. with ft. drawdown after hrs.		
tesian flow g.p.m.		
perature of water Depth artesian flow encounteredft.	Work started VUNE 13 1970 Comp.	leted Very // 1970
(9) CONSTRUCTION:	Date well drilling machine moved off of wel	
	Drilling Machine Operator's Certification	n:
Well seal—Material used	This well was constructed under n	y direct supervision.
Diameter of well bore to bottom of seal	Materials used and information reports best knowledge and belief.	ed above are true to my
Diameter of well bore below seal in.	[Signed] of okusan	Date <i>AUG</i> 3, 1970
Number of sacks of cement used in well seal sacks	(Drilling Machine Operator)	
Number of sacks of bentonite used in well seal sacks	Drilling Machine Operator's License No),
Brand name of bentonite		
Number of pounds of bentonite per 200 gallons	Water Well Contractor's Certification:	
of water	This well was drilled under my jurisdiction and this report is	
Was a drive shoe used? Yes No Plugs Size: location ft.	true to the best of my knowledge and h	
Did any strata contain unusable water? Yes No	Name KELLER WELL DR. (Person, firm or corporation)	(Type or print)
Type of water? depth of strata		ROAD, MILW. ORE
Method of sealing strata off	[Signed] OCKella	
Was well gravel packed? ☐ Yes ☐ No Size of gravel:	Water Well Co	ـــــــــــــــــــــــــــــــــــــ
Gravel placed fromft. toft.	Contractor's License No. 462 Date	MUG J , 19/0