

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 7316 within 30 days from the date of well completion.

RECEIVED WATER WELL REPORT SEP 30 1969 STATE ENGINEER SALEM, OREGON

STATE OF OREGON (Please type or print) Do not write above this line

CLATSOP AMHS 423

State Well No. 113-25

State Permit No.

(1) OWNER:

Name W. A. Nassikhin Address Rt 3 Box 712 Box 9, Oreg.

(2) TYPE OF WORK (check):

New Well [checked] Deepening [] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [] Driven [] Cable [checked] Jetted [] Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [checked] Municipal [] Irrigation [] Test Well [] Other []

CASING INSTALLED:

6" Diam. from 0 ft. to 118 ft. Gage 550

PERFORATIONS:

Perforated? [] Yes [checked] No

Type of perforator used

Size of perforations in. by in. perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [] Yes [checked] No

Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 51 ft. below land surface Date Sept 3-69

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [] Yes [] No If yes, by whom? Yield: 20 gal./min. with 10 ft. drawdown after 2 hrs.

(10) CONSTRUCTION:

Well seal—Material used sand & cement Depth of seal 10.5 ft. Diameter of well bore to bottom of seal 8 in.

(11) LOCATION OF WELL:

County Clatsop Driller's well number 1/4 Section 25 T. 15 R. 3E W.M.

Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing to bottom

Depth drilled 119 ft. Depth of completed well 119 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows include: Top soil, yellow clay, sticky red clay, Tuff, Tuff & cobbles, cemented boulders, soft red clay ardsh, black cement gravel, loose water bearing.

8" surface pipe set to 73'

SE 10A-21- Myers Sub. 120 gal. tank.

Work started Aug 25 1969 Completed Sept 3 1969

Date well drilling machine moved off of well Sept 3 1969

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Douglas H. [Signature] Date 9-29 1969

Drilling Machine Operator's License No. 596

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME A. O. Olsen (Person, firm or corporation) (Type or print)

Address 18211 SE Powell Astoria

[Signed] A. O. Olsen (Water Well Contractor)

Contractor's License No. 282 Date Sept 22 1969