

RECEIVED CLAC 04414 JUN 9 1961 WATER WELL REPORT STATE ENGINEER STATE OF OREGON G2024

30B

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

State Well No. 2/2 - 17 State Permit No.

(1) OWNER: Name CHARLES F. THOMAS Address RIVER ROAD, GLADSTONE, OREGON

(2) LOCATION OF WELL: County Clackamas Owner's number, if any - G-2024 1/4 Section 19 T. 2 S. R. 2 E. W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check): New Well [X] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check): Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other [] (5) TYPE OF WELL: Rotary [X] Cable [X] Dug [] Driven [] Jetted [] Bored []

(6) CASING INSTALLED: 10" Diam. from 0 ft. to 56 ft. Gage 1/2" Threaded [] Welded [X]

(7) PERFORATIONS: Perforated? [X] Yes [] No Type of perforator used TORCH SIZE of perforations 8" X 1/8" in. by 120 perforations from 36 1/2 ft. to 56 1/2 ft.

(8) SCREENS: Well screen installed [] Yes [X] No Manufacturer's Name Type Slot size Set from ft. to ft.

(9) CONSTRUCTION: Was well gravel packed? [X] Yes [] No Size of gravel: 3/4" Gravel placed from 56 ft. to 64 ft. Was a surface seal provided? [X] Yes [] No To what depth? 20 ft. Material used in seal - clay

(10) WATER LEVELS: 1961 Static level 54 ft. below land surface Date April 27 Artesian pressure lbs. per square inch Date

Log Accepted by: Charles F. Thomas June 7, 1961 (Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [X] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Bailer test 60 gal./min. with 1 ft. drawdown after 3 hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [] Yes [X] No

(12) WELL LOG: Diameter of well 10 inches. Depth drilled 64 ft. Depth of completed well 56 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Top soil, river silt, med. gravel, coarse sand, free gravel and sand, Red clay.

Work started April 14 1961 Completed Apr. 27 1961

(13) PUMP: Manufacturer's Name Fairbanks-Morse Type Submersible Turbine H.P. 15

Well Driller's Statement: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Skyles Drilling & Supply (Person, firm, or corporation) (Type or print) Address 19215 S. E. McLoughlin Blvd. Gladstone, Oregon Driller's well number [Signed] George W. Skyles (Well Driller) License No. 58 Date April 27, 1961