

CLAC

RECEIVED CLAC RECEIVED

04431

APR 9 1965 WATER WELL REPORT

2/2-33

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97330 within 30 days from the date of well completion.

STATE ENGINEER STATE OF OREGON SALEM, OREGON

State Well No. 2/2-33
State Permit No.

(1) OWNER:
Name OREGON CITY PUBLIC SCHOOLS
Address OREGON CITY, ORE.

(2) LOCATION OF WELL:
County CLACK. Driller's well number 4189
1/4 Section 33 T. 23 R. 2E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
Well [X] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic [] Industrial [] Municipal []
Irrigation [] Test Well [] Other [X]
(5) TYPE OF WELL:
Rotary [] Driven []
Cable [X] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:
16" Diam. from 0 ft. to 186 ft. Gage 312
12" Diam. from 0 ft. to 472 ft. Gage 330

(7) PERFORATIONS:
Perforated? [] Yes [X] No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed? [] Yes [X] No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal CEMENT GROUT
Depth of seal 26 ft. Was a packer used? NO
Diameter of well bore to bottom of seal 20 in.
Were any loose strata cemented off? [] Yes [X] No Depth
Was a drive shoe used? [X] Yes [] No
Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusuable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 165 ft. below land surface Date 3/4/65
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level. R. STRASSER
Was a pump test made? [X] Yes [] No If yes, by whom? DRILLING CO
Yield: 295 gal./min. with 131 ft. drawdown after 8 hrs.
" 280 " 119 " 1/2"
" 250 " 92 " 1/2"
Baller test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 57° Was a chemical analysis made? [X] Yes [] No

(12) WELL LOG:
Diameter of well below casing 12"
Depth drilled 578 ft. Depth of completed well 578 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with 3 columns: MATERIAL, FROM, TO. Rows include BROWN CLAY AND SAND, SANDY CLAY (BROWN), SANDY CLAY (BLUE), SANDY CLAY (GREY), BROWN SANDSTONE, BROWN SAND, SANDY CLAY (GREY), GREY AND BLUE STICKY CLAY, GREY SANDY CLAY, REDDISH BROWN CLAY, BROWN CLAY, GREY CEMENTED GRAVEL, FRACTURED BROWN ROCK, HARD BROWN ROCK, HARD BLACK ROCK, BROWN ROCK, HARD BLACK ROCK, DARK RED BROKEN ROCK, HARD BLACK ROCK.

Work started NOV. 30 1964 Completed MAR 26 1965
Date well drilling machine moved off of well MAR 30 1965

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME R.J. STRASSER DRILLING CO.
Address 8110 SE SUNSET LANE PORTLAND ORE
Drilling Machine Operator's License No. 56 AND 57
[Signed] Robert L. Strasser (Water Well Contractor)
Contractor's License No. 10 Date APR 1 1965