

RECEIVED
JUN 10 1959

CLAC
00444

1/3-25 A

File Original and
First Copy with the
STATE ENGINEER,
SALEM, OREGON

STATE ENGINEER CLACKAMAS
SALEM, OREGON STATE OF OREGON

G3464

State Well No. _____

State Permit No. _____

(1) OWNER:

Name Kenneth Stone
Address Rt 3 Box 478
Shesham, Oregon

(2) LOCATION OF WELL:

County Clackamas Owner's number, if any—
1/4 25 Section 13 T. 3E Range W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:

Threaded ☐ Welded ☐
6" Diam. from 0 ft. to 82 ft. Gage 028
3" Diam. from 81 ft. to 92 ft. Gage 028
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? ☒ Yes ☐ No
Type of perforator used Torch cut liner
SIZE of perforations in. by in.
3/16" perforations from 82 ft. to 92 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed ☐ Yes ☒ No
Manufacturer's Name _____
Type _____ Model No. _____
Slot size Set from ft. to ft.
Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? ☐ Yes ☒ No Size of gravel: _____
Gravel placed from ft. to ft.
Was a surface seal provided? ☐ Yes ☐ No To what depth? _____ ft.
Material used in seal—
Did any strata contain unusable water? ☐ Yes ☐ No
Type of water? _____ Depth of strata _____
Method of sealing strata off Cemented behind pipe

(10) WATER LEVELS:

Static level 38 ft. below land surface Date Sept. 58
Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] _____ Date _____, 19____
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? driller
Yield: 110 gal./min. with 40 ft. drawdown after 2 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

(12) WELL LOG:

Diameter of well 6 inches.
Depth drilled 92 ft. Depth of completed well 92 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
yellow clay	0	7
cobbles & boulders	7	28
cemented cobbles	28	41
cement gravel	41	79
Loose gravel	79	92
water in gravel	80	92

Work started Sept 1958 Completed Sept 1958

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME P. O. Olsen
(Person, firm, or corporation) (Type or print)

Address Rt 1 Box 565 Shesham

Driller's well number _____

[Signed] P. O. Olsen
(Well Driller)

License No. 131 Date Oct, 1958