NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

CLACKAMAS 00451

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED
MAR 26 1974
STATE ENGINEER
SALEM, OREGON

State Well No. 1S/3E-25
State Permit No.

(1) OWNER:
Name Mitch SAKAUYE
Address 9831 SE. 282nd Boring ore.

(2) TYPE OF WORK (check):
New Well ☐ Deepening ☒ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED:
Threaded ☐ Welded ☒
6 PVC" Diam. from 0 ft. to 165 ft. Gage .250
5" Diam. from 152 ft. to 332 ft. Gage .188
" Diam. from ft. to ft. Gage

PERFORATIONS:
Perforated? ☒ Yes ☐ No.
Type of perforator used Saw CUT
Size of perforations 1/8 in. by 6 in.
200 perforations from 270 ft. to 332 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? LANZ
Yield: 50 gal./min. with 66 ft. drawdown after 3 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 53° Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used
Well sealed from land surface to ft.
Diameter of well bore to bottom of seal in.
Diameter of well bore below seal in.
Number of sacks of cement used in well seal sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite existing
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☐ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☐ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☐ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Clack Driller's well number
¼ ¼ Section 25 T. 1S R. 3E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found ft.
Static level 154 ft. below land surface. Date 3/29/74
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 6
Depth drilled 332 ft. Depth of completed well 332 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Gravel, Cemented	243	300	145
Clay, Grey	300	304	
Gravel cemented	304	330	
Gravel, Loose Water Bearing	330	332	154

Work started 3/15 19 74 Completed 3/22 19 74
Date well drilling machine moved off of well 3/25 19 74

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Louis W. Brant (Drilling Machine Operator) Date 3/23 19 74
Drilling Machine Operator's License No. 246

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name LANZ WELL DRILLING (Person, firm or corporation) (Type or print)
Address 15702 S. Neibur Rd.
[Signed] Donald D. Lanz (Water Well Contractor)
Contractor's License No. 565 Date 3-28 19 74

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119