WATER WELL REPORT

CLAC STATE OF OREGON

WATER RESOURCES DEPT. State Permit No. 6-10180

State Well No.

	SALEM, UREGUN	
(1) OWNER:	(10) LOCATION OF WELL:	
Name JACK WESTFALL	County Clackamas Driller's well number 3682	
Address 14897 S.E. 172nd		W.M.
City CI.ACKAMAS State OREGON	Tax Lot # Lot Blk Subdivision	
	Address at well location: 14897 S.E. 172 nd.	
(2) TYPE OF WORK (check):	Clackamas, Oregon	
New Well XX Deepening □ Reconditioning □ Abandon □	(11) WATER LEVEL: Completed well.	
If abandonment, describe material and procedure in Item 12.		_
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 126 18 Static level 150 ft. below land surface. Date 8 – 2	(6 <u>c ft.</u>
Rotary Air 🕱 Driven 🗆 Domestic 💥 Industrial 🗆 Municipal 🗆	Artesian pressure lbs. per square inch. Date	4-0
Rotary Mud Dug I Irrigation Test Well Other		
☐ Bored ☐ Thermal: Withdrawal ☐ Reinjection ☐ :	(12) WELL LOG: Diameter of well below casing	
(5) CASING INSTALLED: Steel X Plastic	Depth drilled 260 ft. Depth of completed well 260	
Threaded □ Welded 🏋	Formation: Describe color, texture, grain size and structure of materials; and thickness and nature of each stratum and aquifer penetrated, with at least one	
6" Diam. from 0 ft. to 258 ft. Gauge 250	for each change of formation. Report each change in position of Static Water	Level
"Diam. fromft. toft. Gauge	and indicate principal water-bearing strata.	
LINER INSTALLED:	MATERIAL From To SW	VL.
	Clay, brown 0 20	
	Lava weathered 20 26	
(6) PERFORATIONS: Perforated? ★ Yes. □ No	Lava, grey 26 91	
Type of perforator used Rotary Air	Gravel, cemented 91 111	
Size of perforations 1/8 in. by 2 in.	Clay, grey 111 113	
1904 perforations from 127 ft. to 256 ft.	Gravel, cemented 113 126	
perforations from ft. to ft.		—
perforations from ft. to ft.	" , partially cemented 126 148 153	
(7) SCREENS: Well screen installed? ☐ Yes ☒No	" , partially cemented 153 160	—
Manufacturer's Name		
Type	, cementeed 100 100	
Diam. Slot Size Set from ft. to ft.	, partially cemented 180 225	
Diam. Slot Size Set from ft. to ft.	", & Sand 225 260 15	<u>0.</u>
Drawdown is amount water level is beyond		
(8) WELL TESTS: below static level below static level		
Was a pump test made? XX Yes XXXX If yes, by whom? D & A Pump		
ld: 60 gal/min with 60 ft. drawdown after 1 hrs.		
" gar/imir. with OO it. diawdown aren' iiis.		
Air test 20 gal./min. with drill stem at 20 ft. X hrs.		
Bailer test 20 gal./min. with 20t. drawdown after 1 hrs.		
	Work started 8-13 19 82 Completed 8-24 1	982
(9) CONSTRUCTION: Special standards: Yes \(\subseteq \) No \(\subseteq \)	Date well drilling machine moved off of well 8-24 1	982
Well seal—Material used Cement w/5% Bentonete	Drilling Machine Operator's Certification:	
Well sealed from land surface to	This well was constructed under my direct supervision. Materials	used
Diameter of well bore to bottom of seal10 in.	and information reported above are true to my best knowledge and be	lief.
Diameter of well bore below seal	[Signed] Date 9-20,19	52
Number of sacks of cement used in well seal	Drilling Machine Operator's License No. 224	
How was cement grout placed?Pumped		
	Water Well Contractor's Certification:	
i co congression and a constant and	This well was drilled under my jurisdiction and this report is tru	ue to
Was pump installed? Yes	the best of my knowledge and belief.	
Was a drive shoe used? X Yes □ No Plugs Size: location ft.	Name SKYLES DRILLING, INC. (Person, firm or corporation) (Type or print)	
Did any strata contain unusable water? 🗆 Yes 🔯 No	Address 1169 Molalla Ave., Oregon City,	OR
Type of Water? depth of strata	722 · 10 00 /	74-1
Method of sealing strata off	[Signed] (Water Well Contractor)	
Was well gravel packed? ☐ Yes 🖫 No Size of gravel:	Contractor's License No553Date	82
Gravel placed from ft. to ft.	Jake	,.