

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

CLAC 04626

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

State Well No. 2/3-7

State Permit No.

(1) OWNER:

Name Fred L. Siri
 Address 7303 S. Lake Rd.
Milwaukie Oregon

(2) LOCATION OF WELL:

County Clackamas Driller's well number
1/4 SW 1/4 Section 7 T. 3S R. 3E W.M.
 Bearing and distance from section or subdivision corner
NW corner of tax lot 18
south 230' East of West
line 100'

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
 Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:

Threaded Welded
10" Diam. from 0 ft. to 330 ft. Gage 250
 " Diam. from ft. to ft. Gage
 " Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
 Type of perforator used drive down single row
 Size of perforations 1/2" in. by 1 1/2" in.
1 row perforations from 150' ft. to 210' ft.
1 row perforations from 300' ft. to 330' ft.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No
 Manufacturer's Name Model No.
 Diam. Slot size Set from ft. to ft.
 Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal side drilled & cemented
 Depth of seal 26' ft. Was a packer used? no
 Diameter of well bore to bottom of seal 2 1/2" in.
 Were any loose strata cemented off? Yes No Depth
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel:
 Gravel placed from ft. to ft.
 Did any strata contain unusable water? Yes No
 Type of water? Depth of strata
 Method of sealing strata off

(10) WATER LEVELS:

Static level 195' ft. below land surface Date
 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom? O.E.J.
 Yield: 75 gal./min. with 63 ft. drawdown after 6 hrs.
 " " " " " "
 " " " " " "
 " " " " " "
 Bailer test gal./min. with ft. drawdown after hrs.
 Artesian flow g.p.m. Date
 Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 10"
 Depth drilled 350 ft. Depth of completed well 350 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
top soil clay some silt	0	28'
surface water set 18'		
some hot weathered cement gravel	28	45
troutdale cemented gravel & boulders	45	110
sandy clay all yellow	110	115'
reddish brown sandy clay	115	125
grey sandy clay some water	125	129
brown sandy clay some water	129	150
brown cobble hard & soft strata	150	160
grey cemented gravel boulders	160	182
brown & reddish clay	182	185
cemented cobble sand	185	196
some water between formation changes:		
clay & gravel	196	202
sticky clay	202	214
grey clay more sand water	214	220
clay	220	225
sticky yellow clay	225	228
grey blue clay sticky	228	246
sticky blue clay sand streaks	246	291
dark blue clay changed to sand	291	299
sand & water	299	303
clay to 325' sand & gravel 334' clay	324	350
Work started <u>Jan 6</u> 19 <u>66</u> . Completed <u>Oct 3</u> 19 <u>66</u>		
Date well drilling machine moved off of well <u>Oct 8</u> 19 <u>66</u>		

(13) PUMP:

Manufacturer's Name Jacuzzi
 Type: submersible H.P. 10

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME O.E. Jannsen Drilling Co.
 (Person, firm or corporation) (Type or print)

Address Box 38 Clackamas Ore 97015

Drilling Machine Operator's License No. 237

[Signed] O.E. Jannsen
 (Water Well Contractor)

Contractor's License No. 3 Date Oct 14, 1966