

CLAC 04699

WATER WELL REPORT

STATE OF OREGON

State Well No. 2/3-10 A

State Permit No.

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

(1) OWNER:

Name K. SUNAMOTO BERRY FARM
Address Rt. 3 Box 964 By Kats Sunamoto BORING OREGON

(2) LOCATION OF WELL:

County CLACKAMAS Owner's number, if any-
1/4 Section 10 T. 2 S. R. 3 E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal []
Irrigation [x] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven []
Cable [x] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:

12" Diam. from 0 ft. to 415 ft. Gage 5/16
8" Diam. from 395 ft. to 467 ft. Gage 5/16

(7) PERFORATIONS:

Perforated? [x] Yes [] No

Type of perforator used Star 4 way drive down
SIZE of perforations 3/8 in. by 1 1/4 in.
12" 168 perforations from 78 ft. to 85 ft.
72 perforations from 100 ft. to 103 ft.
120 perforations from 165 ft. to 170 ft.
3" 120 perforations from 230 ft. to 235 ft.
Line 185 perforations from 430 ft. to 467 ft.

Size 3/16 x 5 inches (Torch)
Type of screens [] Yes [x] No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Type Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? [x] Yes [] No Size of gravel 3/8 to minus
Gravel placed from 430 ft. to 465 ft.
Was a surface seal provided? [x] Yes [] No To what depth? 47 ft.
Material used in seal SAND, GRAVEL & CEMENT
Did any strata contain unusable water? [] Yes [x] No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 50 ft. below land surface Date
Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] (Owner) Date, 19

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Bottner Drilling Co.
Was a pump test made? [x] Yes [] No If yes, by whom?
Yield: 180 gal./min. with 167 ft. drawdown after 2 hrs.
200 " " 170 " " 7 "
250 " " 170 " " 7 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? [] Yes [x] No

(12) WELL LOG:

Diameter of well 12 inches.
Depth drilled 500 ft. Depth of completed well back filled to 465 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Rows include Top Soil, Clay, gravel & boulders, Boulder, Cemented Gravel, Yellow Clay & coarse gravel, Water approx 4.0 GPM, Blue Clay, Cemented gravel, Blue Clay, Gray Clay, Yellow Clay, Sand stone w/ seams of water, Blue Clay.

Work started July 5 19 60 Completed SEPT 2 19 60

(13) PUMP:

Manufacturer's Name
Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME HAAKON I. BOTTNER DRILLING CO.
(Person, firm, or corporation) (Type or print)

Address 1154 N. E. GLISAN ST.
PORTLAND 20, ORE.

Driller's well number

[Signed] H. Bottner (Well Driller)

License No. 109 Date Oct. 20, 19 60