

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

OBSERVATION WELL WATER WELL REPORT

CLAC
04760
5492

RECEIVED
JAN 14 1968

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

STATE ENGINEER STATE OF OREGON
(Please type or print)
(Do not write above this line)

Well No. 2/3-10 bab
State Permit No. _____

(1) OWNER: u
Name Mr. M. Fujimoto
Address Rt. 3 Box 282 Boring Oregon

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:
Threaded Welded
" Diam. from 0 ft. to 252 ft. Gage .330
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:
Perforated? Yes No.
Type of perforator used Star 4 Way Drive Down
Size of perforations 3/8 in. by 1 1/2 in.
456 perforations from 227 ft. to 246 ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.
Static level 120 ft. below land surface Date _____
Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS: Drawdown is amount water level is lowered below static level Bottner
Was a pump test made? Yes No If yes, by whom? Drlg. Co.
200 gal./min. with 58 ft. drawdown after _____ hrs.
300 " " 75 " " _____ " "
350 " " 95 " " Total 24 "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 53 Was a chemical analysis made? Yes No

(10) CONSTRUCTION:
Well seal—Material used Puddled Clay
Depth of seal 170 ft.
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:
County Clackamas Driller's well number _____
1/4 1/4 Section 10 T. 2 S R. #38 W.M.
Bearing and distance from section or subdivision corner _____

(12) WELL LOG: Diameter of well below casing _____
Depth drilled 305 ft. Depth of completed well 305 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Clay, Brown	0	23	
Clay, Brown w/ gravel	23	59	
Gravel, cemented	59	88	
Clay, brownish, sticky	88	97	
Gravel, cemented	97	120	
Clay, Grayish sandy	120	171	
Clay, white	171	184	
Clay, blue	184	193	
Clay, brown	193	205	
Cemented, Gravel	205	237	
Gravel, Med. Water, Brng.	237	245	
Gravel, Cemented	245	270	
Clay, blue	270	283	
Gravel, very little water	283	297	
Clay, blue/	297	305	

Work started _____ 19 _____ Completed 27 March 1953
Date well drilling machine moved off of well _____

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] _____ Date _____, 19____
(Drilling Machine Operator)

Drilling Machine Operator's License No. None in 1953

Water Well Contractor's Certification: as of Oct. 21 68
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME HAAKON BOTTNER DRILLING COMPANY
(Person, firm or corporation) (Type or print)
Address 3424 S.E. 174th. AVE. Portland, Ore.
[Signed] Haakon Bottner
(Water Well Contractor)
Contractor's License No. 109 Date 11/23, 1968