NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
AUG 01979
WATER RESOURCES DEPT.
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

CLAC
04714

State Well No. 2S/3E-11
State Permit No.

(1) OWNER:
Name Marion Bivel JR
Address 3017 SE Sherrel Milwaukie ORE 97222

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☑ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED: Threaded ☐ Welded ☑
6" Diam. from 0 ft. to 520 ft. Gage .250
Pvc 4" Diam. from 500 ft. to 580 ft. Gage .188
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☑ Yes ☑ No.
Type of perforator used SAW
Size of perforations 1/8 in. by 6 in.
110 perforations from 520 ft. to 580 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☑ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 10 gal./min. with 210 ft. drawdown after 2 hrs.
Artesian flow g.p.m.
Temperature of water 53 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Cement grout
Well sealed from land surface to 130 ft.
Diameter of well bore to bottom of seal 8-10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 30 sacks
How was cement grout placed? Cement was Pressure grouted with trimmie pipe from 130' to 0'
Was a drive shoe used? ☑ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☑ Yes ☐ No Size of gravel: 1/4
Gravel placed from 520 ft. to 580 ft.

(10) LOCATION OF WELL:
County Clack Driller's well number
¼ ¼ Section 11 T. 2S R. 3E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 560 ft.
Static level 345 ft. below land surface. Date 7/31/79
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 0
Depth drilled 585 ft. Depth of completed well 580 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	2	0
Clay Red	2	16	0
Clay Gray	16	49	0
Sandstone Yellow	49	96	0
Cemented Gravel	96	146	0
Sandstone Yellow	146	320	0
Clay Blue	320	310	0
Clay Gray	310	331	0
Clay Blue	331	462	0
Clay Gray	462	532	0
Blue Clay	532	560	0
Blue Shale W.B.	560	562	345
Blue Clay	562	585	345

Work started 6/27 1979 Completed 7/26 1979
Date well drilling machine moved off of well 7/26 1979

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Brad Brant (Drilling Machine Operator) Date 7/31, 1979
Drilling Machine Operator's License No. 861

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name LANZ WELL DRILLING (Person, firm or corporation) (Type or print)
Address 15702 S. Meibur Rd. Oregon City
[Signed] Donald H. Lanz (Water Well Contractor)
Contractor's License No. 565 Date 7-31, 1979

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119