NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

CLAC 04787

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED
APR 22 1975
STATE ENGINEER
SALEM, OREGON

State Well No. 2S/3E-13 CC
State Permit No.

(1) OWNER:
Name Lloyd Bell
Address P.O. Box 101
Boring, Ore 97009

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☑ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☑
6 5/8" Diam. from 0 ft. to 46 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☐ Yes ☑ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name Screen was recommended - Customer declined
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☑ Yes ☐ No If yes, by whom? driller
Yield: 20 gal./min. with 12 ft. drawdown after 1 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 50 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Cement-bentonite-pudclay
Well sealed from land surface to 23 ft.
Diameter of well bore to bottom of seal 9 5/8 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 1 sacks
Number of sacks of bentonite used in well seal 50 lbs sacks
Brand name of bentonite National
Number of pounds of bentonite per 100 gallons of water 1:5 ratio lbs./100 gals.
Was a drive shoe used? ☑ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Clackamas Driller's well number 753
SW ¼ SW ¼ Section 13 T. 2S R. 3E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 44 ft.
Static level 23 ft. below land surface. Date 2-28-75
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing
Depth drilled 48 ft. Depth of completed well 46 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Clay brown - Sandy	0	20	
Consolidated Conglomerate	20	43	
Gravel large with Coarse Sand	43	48	

Work started Feb 26 1975 Completed Feb 28 1975
Date well drilling machine moved off of well Feb 28 1975

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Ross Jannsen Date March 5 1975
(Drilling Machine Operator)
Drilling Machine Operator's License No. 399

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Ross Jannsen Well Drilling
(Person, firm or corporation) (Type or print)
Address Rt. 1 Box 485 Estacada, Ore 97023
[Signed] Ross Jannsen
(Water Well Contractor)
Contractor's License No. 433 Date March 5, 1975

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*46056-110