NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion

NC 60490 CLAC

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED JAN 27 1975 STATE ENGINEER SALEM, OREGON

State Well No. 15/3E-26db
State Permit No.

(1) OWNER:
Name WALLACE BOTHUM
Address RT 3 BOX 798-B GRESHAM ORE

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 165 ft. Gage 250
5" Diam. from 155 ft. to 200 ft. Gage 10
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☒ Yes ☐ No.
Type of perforator used TORCH
Size of perforations 1/8 in. by 10 in.
30 perforations from 155 ft. to 200 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 20 gal./min. with 20 ft. drawdown after 2 hrs.
Artesian flow g.p.m.
Temperature of water 52 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used CEMENT
Well sealed from land surface to 32 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 6 sacks
Number of sacks of bentonite used in well seal — sacks
Brand name of bentonite —
Number of pounds of bentonite per 100 gallons of water — lbs./100 gals.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County CLACKAMAS Driller's well number
NW ¼ SE ¼ Section 26 T. 1S R. 3 E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 80 ft.
Static level 130 ft. below land surface. Date 12/11/74
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 207 ft. Depth of completed well 200 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
SOIL BROWN	0	3	
RED CLAY + BOULDERS	3	21	
RED CLAY	21	32	
CEMENTED GRAVEL	32	207	130

Work started 9/20 19 74 Completed 12/11 19 74
Date well drilling machine moved off of well 12/12 1974

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Wallace L. Garrsland Date 12/12, 1974
(Drilling Machine Operator)
Drilling Machine Operator's License No. 380

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name GARRSLAND DRILLING CO
(Person, firm or corporation) (Type or print)
Address P.O. BOX 31 EAGLE CREEK 97022
[Signed] Wallace L. Garrsland
(Water Well Contractor)
Contractor's License No. 543 Date 12/12, 1974

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45056-119