

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

State Well No. 2/3-23F  
 State Permit No. \_\_\_\_\_

**(1) OWNER:**  
 Name CLACKAMAS COUNTY PARK  
 Address BARTON

**(11) WELL TESTS:** Drawdown is amount water level is lowered below static level  
 Was a pump test made?  Yes  No If yes, by whom?  
 Yield: gal./min. with ft. drawdown after hrs.  
 " " " " "  
 " " " " "  
 Bailor test 6 gal./min. with 20 ft. drawdown after 2 hrs.  
 Artesian flow g.p.m. Date  
 Temperature of water 32 Was a chemical analysis made?  Yes  No

**(2) LOCATION OF WELL:**  
 County CLACKAMAS Owner's number, if any—  
SE 1/4 NW 1/4 Section 23 T. 25 R. 3 E W.M.  
 Bearing and distance from section or subdivision corner  
Corn NE. Corner of SE 1/4

**(12) WELL LOG:** Diameter of well 6 inches.  
 Depth drilled 142 ft. Depth of completed well 138 ft.  
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

**(3) TYPE OF WORK (check):**  
 New Well  Deepening  Reconditioning  Abandon   
 If abandonment, describe material and procedure in Item 11.

**(4) PROPOSED USE (check):**  
 Domestic  Industrial  Municipal   
 Irrigation  Test Well  Other

**(5) TYPE OF WELL:**  
 Rotary  Driven   
 Cable  Jetted   
 Dug  Bored

**(6) CASING INSTALLED:** Threaded  Welded   
6" Diam. from 0 ft. to 115 ft. Gage 3 1/2"  
 " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
 " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

MATERIAL	FROM	TO
<u>LOOSE GRAVEL AND CORBBLE STONES</u>	<u>0</u>	<u>28</u>
<u>BLUE CLAY</u>	<u>28</u>	<u>118</u>
<u>FINE GRAINED BROWN SANDSTONE</u>	<u>118</u>	<u>138</u>
<u>BROWN CLAY WITH MICA WATER FULL OF MICA</u>	<u>138</u>	<u>142</u>
<u>WELL MAY MAKE 6 GPM IF PULLED EASY</u>		

**(7) PERFORATIONS:** Perforated?  Yes  No  
 Type of perforator used  
 SIZE of perforations in. by in.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) SCREENS:** Well screen installed  Yes  No  
 Manufacturer's Name \_\_\_\_\_  
 Type \_\_\_\_\_ Model No. \_\_\_\_\_  
 \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**  
 Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
 Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 Was a surface seal provided?  Yes  No To what depth? 115 ft.  
 Material used in seal—CASED OFF  
 Did any strata contain unusable water?  Yes  No  
 Type of water? SURFACE Depth of strata 28  
 Method of sealing strata off CASED

**(10) WATER LEVELS:**  
 Static level 80 ft. below land surface Date 1/24/61  
 Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

Log Accepted by: \_\_\_\_\_  
 [Signed] \_\_\_\_\_ Date 3-15, 1961  
 (Owner)

Work started 1/9 1961. Completed 1/24 1961

**(13) PUMP:**  
 Manufacturer's Name \_\_\_\_\_  
 Type: \_\_\_\_\_ H.P. \_\_\_\_\_

**Well Driller's Statement:**  
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
 NAME WILLIAM D. STENNETT  
 (Person, firm, or corporation) (Type or print)  
 Address 361 WARNER MILNE ROAD OREGON CITY  
 Driller's well number \_\_\_\_\_  
 [Signed] William D. Stennett  
 (Well Driller)  
 License No. 5 Date 3/3, 1961