

NOTICE TO WATER WELL CONTRACTOR
 The original and first copy
 of this report are to be
 filed with the
 STATE ENGINEER, SALEM 10, OREGON
 within 30 days from the date
 of well completion.

CLAC
 51830
 OCT 20 1964

RECEIVED
 OCT 20 1964

WATER WELL REPORT
 STATE OF OREGON
 State Well No. 2/3-28M
 State Permit No. _____

(1) OWNER:

Name Logan Egg Farm
 Address Rt. 5 Box 518
Oregon City, Oregon

(2) LOCATION OF WELL:

County Clackamas Driller's well number _____
 1/4 Section 28 T. 2 S R. 3 N W.M.
 Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:

Threaded Welded
 10" Diam. from 0 ft. to 71 ft. Gage .277
 8" Diam. from 67 ft. to 150 ft. Gage .250

(7) PERFORATIONS:

Perforated? Yes No
 Type of perforator used torch
 Size of perforations 1/8 in. by 12 in.
 900 perforations from 71 ft. to 131 ft.
 60 perforations from 131 ft. to 141 ft.

(8) SCREENS:

Well screen installed Yes No
 Manufacturer's Name _____
 Type _____ Model No. _____
 Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite and clay
 Depth of seal 75 ft. Was a packer used? no
 Diameter of well bore to bottom of seal 10 in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ Depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:

Static level 42 ft. below land surface Date 9/9/64
 Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom? driller
 Yield: 400 gal./min. with 90 ft. drawdown after 1/3 hrs.
 " 90 " 90 " 4 "
 " " " " "
 Bailor test 50 gal./min. with 8-10 ft. drawdown after 3/4 hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing _____
 Depth drilled 227 ft. Depth of completed well 150 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Sandy clay soil	0	3
decomposed sand	3	27
rocky clay	27	75
part cement gravel & water	75	80
rocky clay	80	112
water-bearing sandstone	112	127
sandstone nonwaterbearing	127	145
grey silty clay	145	159
grey brown clay	159	167
cemented gravel	167	173
brown sandy clay	173	201
cemented gravel	201	227

Loss of static head was noted after last day of drilling, backfilling did not stop loss of head so well was filled to 150.

Work started 9/4/64 19 Completed 10/8/64 19
 Date well drilling machine moved off of well 10/8/64 19

(13) PUMP:

Manufacturer's Name _____
 Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME George Zent & Sons
 (Person, firm or corporation) (Type or print)

Address 4305 N.E. 44 th St. Vancouver, Wash

Drilling Machine Operator's License No. 205

[Signed] George Zent
 (Water Well Contractor)

Contractor's License No. 228 Date 10/14/64