

WATER WELL REPORT
STATE OF OREGON

RECEIVED

MAY 25 1982

State Well No. 25/4E-262

State Permit No.

CLAC05365

WATER RESOURCES DEPT
SALEM, OREGON

(1) OWNER:

Name Chatelain's Nursery
Address 37071 S.E. Kelso Road
City Boring State Oregon

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air ☒ Driven ☐
Pneum. Mud ☐ Dug ☐
☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐
Thermal: ☐ Withdrawal ☐ Reinjection ☐

(5) CASING INSTALLED:

Steel ☒ Plastic ☐
Threaded ☐ Welded ☒

10" Diam. from 0 ft. to 190 ft. Gauge 2.50
" Diam. from ft. to ft. Gauge

(6) LINER INSTALLED:

8" Diam. from 0 ft. to 430 ft. Gauge 1.88

(6) PERFORATIONS:

Perforated? ☒ Yes ☐ No

Type of perforator used Torch
Size of perforations 1/8 in. by 6 in.
1,000 perforations from 295 ft. to 425 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☒ Yes ☐ No

Manufacturer's Name
Type Model No.
Diam. 8" Slot 0.09 Set from 295 ft. to 395 ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

pump test made? ☒ Yes ☐ No If yes, by whom? Ted
Yield: 100 gal./min. with 90 ft. drawdown after 6 hrs.

Air test gal./min. with drill stem at ft. hrs.

Bailer test gal./min. with ft. drawdown after hrs.

ian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes ☐ No ☒

Well seal—Material used cement 4% bent

Well sealed from land surface to 80 ft.

Diameter of well bore to bottom of seal 14 in.

Diameter of well bore below seal 10 in.

Number of sacks of cement used in well seal 42 sacks

How was cement grout placed? grout pumped

Was pump installed? yes Type sub HP 25 Depth 385 ft.

Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.

Did any strata contain unusable water? ☒ Yes ☐ No

Type of Water? NOT ENOUGH depth of strata 60

Method of sealing strata off

Was well gravel packed? ☒ Yes ☐ No Size of gravel: 3/8

Gravel placed from ft. to 420 ft.

(10) LOCATION OF WELL:

County CLACK Driller's well number
SE 1/4 NW 1/4 Section 2 T. 25 R. 4E W.M.
Tax Lot # Lot Blk Subdivision
Address at well location: 37071 S.E. Kelso Rd.
Boring, Oregon

(11) WATER LEVEL: Completed well.

Depth at which water was first found 60 ft.
Static level 285 ft. below land surface. Date 5/24/82
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8" x 10"

Depth drilled 460 ft. Depth of completed well 450 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Clay	0	60	
Clay & Gravel	60	120	40'
Rock with loose gravel streaks	120	140	
Clay & Gravel	140	190	
Sandstone	190	260	
Fine cemented gravel	260	340	
Coarse sand and gravel	340	360	
Clay and Sand	360	420	
Clay	420	450	
Sand	450	455	
Clay	455	460	

Work started 2-5 19 82 Completed 5/24 19 82
Date well drilling machine moved off of well 5/24 19 82

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Ted W. Pullman Date 5/24, 1982
(Drilling Machine Operator)

Drilling Machine Operator's License No. 8.13

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Ted Pullman Well Drilling (Type or print)

Address 4245 W. Powell

[Signed] Ted W. Pullman (Water Well Contractor)

Contractor's License No. 616 Date May 24, 1982

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the


WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

SP12658-690



Oregon Water Resources Department
725 Summer Street NE, Suite A
Salem Oregon 97301
(503) 986-0900
www.oregon.gov/owrd

Application for Well ID Number



Do not complete if the well already has a Well Identification Number.

I. OWNER INFORMATION

Current Owner Name (please print): Mike Dutton

Mailing Address: 36780 SE Dunn Rd. Sandy

City, State, Zip: 97055

Mail ~~Well ID~~ to: ☐ SAME AS ABOVE ☐ In Care Of (C/O)

Name & Address: **N/A - Well inspector attached well label while on site.** * No packet required

City, State, Zip: _____

II. WELL LOCATION INFORMATION (Please fill out as completely as possible)

Township: 2S (North / South) Range: 4E (East / West) Section: 2 NE 1/4 of the NW 1/4

Tax Lot (usually last 3-5 numbers of Tax Map #): 3703 County Clackamas

GPS Coordinates: 45.42893413 -122.28422821 per GNIS site/WR

Street Address of Well, City: 36780 SE Dunn Rd, Sandy Oregon

If the property had a different street address in the past: _____

III. GENERAL WELL INFORMATION (Please fill out as completely as possible, AND attach copy of Well Report, if available)

Use of Well (domestic, irrigation, commercial, industrial, monitoring): Irrigation

Date Well Constructed (or property built): 5-24-1982 Total Well Depth: 460' Casing Diameter: 10"

Owner at time the well was constructed (if known): Chatelain's Nursery Well Report # (if known): CLAC 5365

Other Information: _____

SUBMITTED BY (please print): Josh Lucas (Well Inspector)

PHONE: 971-428-7192 EMAIL &/or FAX: _____

To send the completed application, you may MAIL it to: Oregon Water Resources Dept. 725 Summer St NE, Suite A, Salem, Oregon 97301.
Or EMAIL the completed PDF form to: Ladeena.K.Ashley@water.oregon.gov, or FAX it to: (503) 986-0902.

For Official Use Only by the Oregon Water Resources Department:

Received Date:

10-18-23

Well Report Number:

CLAC 5365

Well Identification #:

L-149161