

RECEIVED

25/4E-300

STATE OF OREGON WATER WELL REPORT AUG - 7 1986 (as required by ORS 537.765) WATER RESOURCES DEPT

CLAC 05410

(1) OWNER: DON EKLUND, Owner's Well Number: 211, Address: 1536 Bluff Rd. Sandy, ORE 97055

(9) LOCATION OF WELL by legal description: County: CLACK, Township: 2-5, Section: 3, Street Address of Well: Mountain Sadows Estates Kelso ORE. 14323 S.E. Nicholas

(2) TYPE OF WORK: [X] New Well, [ ] Deepen, [ ] Recondition, [ ] Abandon. (3) DRILL METHOD: [ ] Rotary Air, [ ] Rotary Mud, [X] Cable, [ ] Other

(10) STATIC WATER LEVEL: 195 ft. below land surface. Date: 7/14/86

(4) PROPOSED USE: [ ] Domestic, [X] Community, [ ] Industrial, [ ] Irrigation, [ ] Thermal, [ ] Injection, [ ] Other

(11) WELL LOG: Ground elevation \_\_\_\_\_

(5) BORE HOLE CONSTRUCTION: Depth of Completed Well: 505 ft. Special Standards date of approval: NONE

Table with columns: HOLE diameter, SEAL Material, Amount sacks or pounds. Rows show 7" and 8" hole diameters with 25' seal lengths and 24 sacks of cement.

WELL LOG table with columns: Material, From, To, WB?, SWL. Lists materials like Top Soil, Clay Red, Clay Yellow, Clay & Gravel, Boulders & Clay, City Yellow Sandy, Cemented Gravel, Clay Brown Sandy, Clay Blue, Blue Shale W.B., Clay Blue, and Black Shale with depth ranges and SWL values.

How was seal placed? Method [X] A, [ ] B, [ ] C, [ ] D, [ ] E. Backfill placed from 25 ft. to 505 ft. Material: 3/8. Gravel placed from 25 ft. to 505 ft. Size of gravel: 3/8.

Date started: 4/24/86, Completed: 7/10/86

(6) CASING/LINER: Table with columns: Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded. Shows casing from 8" to 209' and liner from 7" to 505'.

(unbonded) Water Well Constructor Certification: I constructed this well in compliance with Oregon well construction standards. Signed: \_\_\_\_\_ Date: \_\_\_\_\_

Location of shoe(s): 209

(7) PERFORATIONS/SCREENS: [X] Perforations, Method: truck, [ ] Screens, Type: \_\_\_\_\_ Material: \_\_\_\_\_

Table with columns: From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner. Shows slot size 7/8, number 540, diameter 7.10.

(bonded) Water Well Constructor Certification: I accept responsibility for construction of this well and its compliance with all Oregon water well standards. Signed: Brad Brant, Date: 7/14/86, Company: BRANT WELL DRILLING

(8) WELL TESTS: Minimum testing time is 1 hour. [ ] Pump, [X] Bailer, [ ] Air, [ ] Artesian. Yield: 38, 46 gal/min. Pumping level: 185, 191. Time: 1/2 hr, 1 hr.

Temperature of water: 52. Depth Artesian Flow Found: \_\_\_\_\_. Was a water analysis done? [ ] Yes, [ ] No. Did any strata contain water not suitable for intended use? [ ] Too little, [ ] Salty, [ ] Muddy, [ ] Odor, [ ] Colored, [ ] Other: NO. Depth of strata: \_\_\_\_\_