

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED JUL 26 1972

WATER WELL REPORT

STATE ENGINEER OF OREGON SALEM, OREGON (Please type or print)

CLAC 05432

State Well No. 2S/4E<sup>70</sup>-3CC State Permit No.

OWNER: Name FAYETTE WEEDIN Address ROUTE 2 BOX 778 TROUTDALE ORE

(2) LOCATION OF WELL: County Clackamas Driller's well number 4128 SW 1/4 SW 1/4 Section 3 T. 25 R. 4E W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check): New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ] If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [X] Test Well [ ] Other [ ] (5) TYPE OF WELL: Rotary [ ] Driven [ ] Cable [X] Jetted [ ] Dug [ ] Bored [ ]

(6) CASING INSTALLED: Threaded [ ] Welded [X] 8" Diam. from 0 ft. to 4.95 ft. Gage 2.77

(7) PERFORATIONS: Perforated? [ ] Yes [ ] No Type of perforator used Size of perforations 1/4 in. by 1/4 in. 240 perforations from 152 ft. to 160 ft. 240 perforations from 250 ft. to 258 ft. 240 perforations from 384 ft. to 392 ft.

(8) SCREENS: Well screen installed [ ] Yes [ ] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION: Well seal—Material used in seal CEMENT GRANT Depth of seal 30 ft. Was a packer used? YES Diameter of well bore to bottom of seal 1.2 in. Were any loose strata cemented off? [ ] Yes [X] No Depth Was a drive shoe used? [X] Yes [ ] No Was well gravel packed? [ ] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Do any strata contain unusable water? [ ] Yes [X] No Depth of strata Method of sealing strata off

(10) WATER LEVELS: Static level 140 ft. below land surface Date 7/13/62 Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? [X] Yes [ ] No If yes, by whom? R.J. STRASSER Yield: 148 gal./min. with 70 ft. drawdown after 8 hrs.

(12) WELL LOG: Diameter of well below casing Depth drilled 495 ft. Depth of completed well 495 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include TOP SOIL, CLAY, CLAY AND GRAVEL, RED CLAY, BROWN SILT, SAND GRAVEL AND SILT (WATER), SANDY CLAY, BLUE CLAY, SAND GRAVEL AND SOME BINDER (WATER), BROWN CLAY, YELLOW CLAY, BROWN SANDY CLAY, BLUE CLAY, CONGLOMERATE (WATER), BLACK CLAY, BLUE GREY CLAY.

Work started MAY 29 1962 Completed JULY 19 1962 Date well drilling machine moved off of well JULY 19 1962

(13) PUMP: Manufacturer's Name Type: H.P.

Water Well Contractor's Certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. NAME R.J. STRASSER DRILLING Co. (Person, firm or corporation) (Type or print) Address 8110 SE SUNSET LANE PORT ORE Drilling Machine Operator's License No. [Signed] Paulo Rudman MANAGER (Water Well Contractor) Contractor's License No. 10 Date JULY 31, 1962