

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

RECEIVED

WATER WELL REPORT

CLAC

RECEIVED

AUG 27 1973

STATE OF OREGON

MAY 9 1973

State Well No. 2S/4E-4

STATE ENGINEER, SALEM, OREGON
within 30 days from the date
of well completion.

STATE ENGINEER
SALEM, OREGON

(Please type or print)

State Permit No. CLAC 05477

(1) OWNER:

Name William C. & Ruby Lee Schneider
Address Rt. 1, Box 130, Boring Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
3 1/2" Diam. from 0 ft. to 100 ft. Gage 188
6" Diam. from 0 ft. to 100 ft. Gage 250
Liner 5" Diam. from 91 ft. to 131 ft. Gage 188

PERFORATIONS:

Perforated? Yes No.

Type of perforator used (Liner only) Torch
Size of perforations 3/16 in. by 8 in.
84 perforations from 100 ft. to 128 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " " "
" " " " " "
Baller test 3 1/4 gal./min. with 29 ft. drawdown after 6 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 28 ft.
Diameter of well bore to bottom of seal 8 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 7 sacks
Number of sacks of bentonite used in well seal 0 sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons
of water lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Clackamas Driller's well number
1/4 1/4 Section 4 T. 2S R. 4E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 23 ft.
Static level 37 ~~2337~~ ft. below land surface. Date 1-17-73
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Cased to bottom
Diameter of well below casing

Depth drilled 131 ft. Depth of completed well 131 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top soil	0	15	
Clay, yellow	15	23	
Boulders (water at 23')	23	63	9
Rock	63	74	
Sand, black	74	80	
Gravel & boulders	80	100	
Rock, seams w/ water	100	125	
Gravel, water bearing	125	131	37

Work started Nov. 21 19 72 Completed Jan. 17 19 73
Date well drilling machine moved off of well Jan 23 19 73

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Earl Baker Date 2/23, 1973
(Drilling Machine Operator)

Drilling Machine Operator's License No. 19D & 431

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name HAAKON BOTTNER DRILLING COMPANY
(Person, firm or corporation) (Type or print)

Address 3424 S.E. 174 AV., PORTLAND, OREGON

[Signed] Haakon Bottner
(Water Well Contractor)

Contractor's License No. 109 Date 2/23/, 1973