NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the WATER WELL REPORT STATE OF OREGON JUL 2 2 1975 State Well No. 25/45-4	
STATE ENGINEER, SALEM, OREGON 97310 (Please type	WATER RESOURCES DEDT
de epened)	bove this line EM. OREGON
(1) OWNER:	(10) LOCATION OF WELL:
Name WILLIAM C.& RUBY LEE SCHNEIDER	County Clackamas Driller's well number
Address 13025 S.E.Orient Drive	1 20 1 7
Boring, Oregon 97005	
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision corner
New Well ☐ Deepening ♣ Reconditioning ☐ Abandon ☐	
If abandonment, describe material and procedure in Item 12.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(11) WATER LEVEL: Completed well.
	Depth at which water was first found ft.
Cable	Static level 45 ft. below land surface. Date
Dug Bored Irrigation Test Well Other	Artesian pressure lbs. per square inch. Date
CASING INSTALLED: Threaded [] Welded T	(10) WELL LOC
6	(12) WELL LOG: Diameter of well below casing
	Depth drilled 200 ft*Depth of completed well 190 ft.
	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,
DEDECOR A MYCAYO	with at least one entry for each change of formation. Report each change in
PERFORATIONS: Perforated? Yes No.	position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used Drive Down	MATERIAL From To SWL
Size of perforations in. by 3/0 in.	Gravel, cemented 110 150
252 perforations from 99 ft. to 120 ft.	Rock, brown, soft 150 153
The perforations from the fit to the fit	Gravel, mdm., water brng. 153 172 61
180 perforations from 155 ft. to 170 ft.	Clay, gray 172 183
(7) SCREENS: Well screen installed? Yes No	Gravel, mdm., water brng. 183 195 51 Sand, yellow, fine 195 200
Manufacturer's Name	Sand, yellow, fine 195 200
Type Model No	*Completed depth, back filled
Diam, Slot size Set from ft, to ft.	with pea gravel *
Diam. Slot size Set from ft. to ft.	Note:
(8) WELL TESTS: Drawdown is amount water level is lowered below static level Bottner	After test pumped statec
Was a pump test made? Yes \(\simeg \) No If yes, by whom? Drilling	
Yield: 25 gal./min. with 30 ft. drawdown after 4 hrs.	
50 " 58 " 6 "	
" 72 " 70 " 24 "	
Bailer test gal./min. with ft. drawdown after hrs.	
Artesian flow g.p.m.	
perature of water Depth artesian flow encountered ft.	Work started Feb. 27 1975 Completed March 28 75
(9) CONSTRUCTION: Did not disturb seal	Date well drilling machine moved off of well April 2 19 75
hát was installed previously	
Well seal—Material used	Drilling Machine Operator's Certification: This well was constructed under my direct supervision.
Well sealed from land surface toft,	Materials used and information reported above are true to my
Diameter of well bore to bottom of sealin. Diameter of well bore below sealin.	best knowledge and belief.
Number of sacks of cement used in well seal sacks	[Signed] (Drilling Machine Oppositor) Date 5/287, 1975
Number of sacks of bentonite used in well seal	Drilling Machine Operator's License No. 902
Brand name of bentonite	
Number of pounds of bentonite per 100 gallons	Water Well Contractor's Certification:
of water lbs./100 gals.	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Was a drive shoe used? Yes No Plugs Size; location ft.	Name HAAKON BOTTNER DRILLING CO.
Did any strata contain unusable water? □ Yes KNo	(Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address 3424 S.E.174th., PORTLAND, OR. 97236
Method of sealing strata off	[Signed] Hashon Bolling,
Was well gravel packed? Yes No Size of gravel:	(Water Well Contractor)
Gravel placed fromft. toft.	Contractor's License No. 109 Date 6 - / 19.7

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119