

STATE OF OREGON
WATER WELL REPORT
 (as required by ORS 537.765)

CLAG
5587

RECEIVED
 JAN 22 1985
 WATER RESOURCES DEPT
 SALEM, OREGON

25/4E-7
 Dup.
 (for official use only)

(1) OWNER:

Name I Selvi Nursey
 Address 30590 S.E. Kelso Rd.
 City Boring State ORE

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven
 Rotary Mud Dug
 Cable Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Thermal: Withdrawal ReInjection
 Other: Piezometric Grounding Test

(5) CASING INSTALLED:

Steel Plastic
 Threaded Welded

....." Diam. from ft. to ft. Gauge

LINER INSTALLED:

Steel Plastic
 Threaded Welded

7" O.D. 240 360 ft. to 360 ft. Gauge 1.88

(6) PERFORATIONS:

Perforated? Yes No
 Size of perforations 1/4 in. by 12 inch in.
480 perforations from 240 ft. to 360 ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name Model No.
 Type Diam. Slot Size Set from ft. to ft.
 Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Ted
 Yield: apx. 180 gal./min. with 30 ft. drawdown after 2 hrs.
 Air test gal./min. with drill stem at ft. hrs.
 Bailer test gal./min. with ft. drawdown after hrs.
 Artesian flow g.p.m.
 Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes No

Well seal—Material used ft.
 Well sealed from land surface to ft.
 Diameter of well bore to bottom of seal in.
 Diameter of well bore below seal in.
 Amount of sealing material sacks pounds
 How was cement grout placed?

Was pump installed? yes Type Sub. HP Depth 315 ft.
 Was a drive shoe used? Yes No Plugs Size: location ft.
 Did any strata contain unusable water? Yes No
 Type of Water? depth of strata
 Method of sealing strata off
 Was well gravel packed? Yes No Size of gravel:
 Gravel placed from ft. to ft.

(10) LOCATION OF WELL by legal description:

County CLACK 1/4 1/4 of Section 7 of
 Township 23, Range 4E, WM.
 (Township is North or South) (Range is East or West)

Tax Lot Lot Block Subdivision
 MAILING ADDRESS OF WELL (or nearest address) 30590 S.E. Kelso Rd., Boring ORE, Well # 2.

(11) WATER LEVEL of COMPLETED WELL:

Depth at which water was first found 270 ft.
 Static level 225 ft. below land surface. Date
 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8"
 Depth drilled 275 ft. Depth of completed well 260 ft.
 Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Lightly Cemented	270		225
GRAVEL WITH Large Boulders.		360	
Blue Clay & Sand	360	375	
Filled in with Pea GRAVEL			
375-360 FT			

Date work started 9-28-84 / completed 10-15-84
 Date well drilling machine moved off of well 10-15-1984

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Date, 19

(bonded) Water Well Constructor Certification:

Bond 2546611 Issued by: SAFCO (number) (Surety Company Name)
 On behalf of Ted Pulliam Well Drilling (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

(Signed) Ted W Pulliam (Water Well Constructor)

(Dated) 10-16-84

NOTICE TO WATER WELL CONSTRUCTOR
 The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
 SALEM, OREGON 97310
 within 30 days from the date of well completion.

SP*46866-690