

CLAC

05611

G 5559

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED WATER WELL REPORT SEP 15 1965 STATE OF OREGON STATE ENGINEER SALEM OREGON

2/4-7cb 2/3-12

State Well No. State Permit No.

(1) OWNER: Name Murray Heitzman Address Boying, Oreg.

(2) LOCATION OF WELL: County Clackamas, Driller's well number 1/4 Section 12 T. 25 R. 3E W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check): New Well X Deepening Reconditioning Abandonment

(4) PROPOSED USE (check): Domestic X Industrial Municipal Irrigation Test Well Other (5) TYPE OF WELL: Rotary Driven Cable X Jetted Dug Bored

(6) CASING INSTALLED: Threaded Welded 8" Diam. from 0 ft. to 230 ft. Gage 277 6" Diam. from 225 ft. to 250 ft. Gage 250

(7) PERFORATIONS: Perforated? X Yes No Type of perforator used Torch cut liner, 22' 8" Size of perforations 1/4 in. by 10 in. 4 per ft. perforations from 230 ft. to 250 ft.

(8) SCREENS: Well screen installed? X Yes No Manufacturer's Name Type Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION: Well seal—Material used in seal cemented, back with clay slurry Depth of seal below 100 ft. Was a packer used? Diameter of well bore to bottom of seal 8 in. Were any loose strata cemented off? X Yes No Depth Was a drive shoe used? X Yes No Was well gravel packed? X Yes No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? X Yes No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS: Static level 202 ft. below land surface Date Feb 25-65 Artesian pressure lbs. per square inch Date March

(11) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? X Yes No If yes, by whom?

Yield: 100 gal./min. with 6 ft. drawdown after 2 hrs. 135 " 7 " 2 " 145 " no reading 1 " Bailer test 30 gal./min. with 0 ft. drawdown after 1 hrs. Artesian flow g.p.m. Date Temperature of water 53 Was a chemical analysis made? X Yes No

(12) WELL LOG: Diameter of well below casing 8" Depth drilled 2.50 ft. Depth of completed well 2.50 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Entries include Top soil, yellow clay, yellow clay and soft gravels, brown clay, Brown sand rocks, water bearing.

drilled 10" hole to 153 set 8" pipe and drove to 230 - drilled open hole in sand rock set 6" perforated liner.

Work started Feb 15 1965 Completed Feb 25 1965 Date well drilling machine moved off of well Feb 26 1965

(13) PUMP: 220 3 Ph SC 750 B6 Manufacturer's Name FE Myers Type: Submersible H.P. 7 1/2 Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME A.O. Olsen (Person, firm or corporation) (Type or print) Address 18211 SE Powell, Bresham, Drilling Machine Operator's License No. 215 [Signed] A.O. Olsen (Water Well Contractor) Contractor's License No. 282 Date Mar 10, 1965