

WATER WELL REPORT
STATE OF OREGON

CLAC
05622

RECEIVED

OCT 25 1983

State Well No. 25/4E Sac
State Permit No. _____

PLEASE TYPE OR PRINT IN INK
WATER RESOURCES DEPT

SALEM, OREGON

(1) OWNER:

Name Ronald Jones
Address 2547 Oak Creek Circle
City Sandy State UTAH Zip 84092

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven Domestic Industrial Municipal
Rotary Mud Dug Irrigation Test Well Other
Cable Bored Thermal: Withdrawal Reinjection

(4) PROPOSED USE (check):

Steel Plastic
Threaded Welded

10" Diam. from +2 ft. to 139 ft. Gauge 250
8" Diam. from 0 ft. to 308 ft. Gauge 277

LINER INSTALLED:

6" Diam. from 300 ft. to 400 ft. Gauge 200 PSI PVC

(6) PERFORATIONS:

Perforated? Yes No

Type of perforator used Rotary Star and Saw
Size of perforations 1 1/4 x 1/4 in. 5 x 1/8 in.
900 perforations from 250 ft. to 285 ft.
350 perforations from 305 ft. to 390 ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____ Type _____ Model No. _____
Diam. _____ Slot Size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot Size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Pump: _____ gal./min. with _____ ft. drawdown after _____ hrs.
Air test 300+ gal./min. with drill stem at 380 ft. | _____ hrs.
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m.

Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Special standards: Yes No

Well seal—Material used CEMENT
Well sealed from land surface to 24 ft.
Diameter of well bore to bottom of seal 14 in.
Diameter of well bore below seal 10 in.
Number of sacks of cement used in well seal 32 sacks
How was cement grout placed? PUMP

Was pump installed? _____ Type _____ HP _____ Depth _____ ft.
Was a drive shoe used? Yes No Plugs _____ Size; location _____ ft.
Did any strata contain unusable water? Yes No
Type of Water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County CLACKAMAS Driller's well number _____
SW 1/4 NE 1/4 Section 8 T. 25 R. 4E W.M. _____
Tax Lot # _____ Lot _____ Blk _____ Subdivision _____

Address at well location: _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 238 ft.
Static level 152 ft. below land surface. Date 7/14/83
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 8

Depth drilled 404 ft. Depth of completed well 400 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

| MATERIAL | From | To | SWL |
|-------------------------------------|------|-----|-----|
| SOIL AND SAW DUST | 0 | 3 | |
| CLAY BROWN | 3 | 19 | |
| CEMENTED GRAVEL WITH LARGE BOULDERS | 19 | 128 | |
| CLAY GRAY | 128 | 144 | |
| CEMENTED GRAVEL | 144 | 238 | |
| SAND FINE | 238 | 247 | 152 |
| CEMENTED GRAVEL | 247 | 298 | 152 |
| SANDSTONE BROWN | 298 | 337 | 152 |
| CLAY BROWN | 337 | 345 | |
| CLAY BLUE | 345 | 358 | |
| SANDSTONE | 358 | 374 | 152 |
| CLAY GRAY | 374 | 404 | |

Work started 6/20 19 83 Completed 7/18 19 83
Date well drilling machine moved off of well 7/18 19 83

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Daniel V. [Signature] Date 8/10, 19 83

Bonded Water Well Constructor Certification:

Bond 2456611 Issued by: SAFCO Surety Company Name _____
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Ted Pullman Well Drilling (Type or print)
Address 4245 W Powell
[Signed] Ted Pullman Water Well Constructor
Date 7/25, 19 83

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

SP#45292-690