

WATER SUPPLY WELL REPORT

(as required by ORS 537.765)

Instructions for completing this report are on the last page of this form

SKYLES DRILLING, INC.

START CARD # W148587

(1) OWNER:

Well Number: 01

Name Audubon Society of Portland
Address 5151 NW Connell Rd.
City Portland State OR Zip 97210

(2) TYPE OF WORK:

X New Well Deepening Alteration (repair/recondition) Abandonment

(3) DRILL METHOD:

X Rotary Air Rotary Mud Cable Auger
X Other Holte

(4) PROPOSED USE:

X Domestic Community Industrial Irrigation
Thermal Injection Livestock Other

(5) BORE HOLE CONSTRUCTION:

Special Construction approval Yes X No Depth of Completed Well 119.5 ft.
Exposives used Yes X No Type Amount

Table with columns: HOLE Diameter, From, To, SEAL Material, From, To, Amount. Row 1: 11.5, 0, 22, Bentonite, 22, 0, 12 Sacks. Row 2: 7.5, 22, 119.5.

How was seal placed: Method A B C D E

X Other Poured

Backfill placed from ft. to ft. Material
Gravel placed from ft. to ft. Size of gravel

(6) CASING/LINER:

Table with columns: Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded. Casing: 6, +1.5, 118.5, .250, X, X.

Liner: None

Drive Shoe used Inside Outside X None

Final location of shoe(s)

(7) PERFORATIONS/SCREENS:

Table with columns: From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner. Perforations: None.

(8) WELL TESTS: Minimum testing time is 1 hour

Pump Bailer X Air Flowing Artesian

Yield gal/min 25 Drawdown Drill stem at 119 Time

Temperature of Water 55 Depth Artesian Flow found

Was a water analysis done? X Yes By whom Driller 1.25 PPM Iron

Did any strata contain water not suitable for intended use? Too little

Salty Muddy Odor Colored Other

Depth of strata:

(9) LOCATION OF WELL by legal description:

County Clackamas Latitude Longitude
Township 2S N or S. Range 6E E or W. of WM.
Section 18 NE 1/4 NW 1/4
Tax lot 201 Lot Block Subdivision
Street Address of Well (or nearest address) 52805 E Marmot Rd., Sandy, OR

(10) STATIC WATER LEVEL:

88 ft. below land surface. Date 6/18/2002
Artesian pressure lb. per square inch. Date

(11) WATER BEARING ZONES:

Depth at which water was first found 106

Table with columns: From, To, Estimated Flow Rate, SWL. Row 1: 106, 119.5, 25, 88.

(12) WELL LOG:

Table with columns: Material, From, To, SWL. Log entries: Top Soil, Brown (0-1), Clay, Brown w/ Boulders (1-17), Claystone mixed w/ Lava, Gray (17-36), Conglomerate, Multicolored (36-119.5). SWL 88.

SKYLES DRILLING INC.
1169 Molalla Ave.
Oregon City, OR 97045

RECEIVED

JUL 02 2002

WATER RESOURCES DEPT.
SALEM, OREGON

Date started 6/17/2002 Completed 6/18/2002

(unbonded) Water Well Constructor Certification:

I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief.

Signed [Signature] WWC Number 1715 Date 6-21-02

(bonded) Water Well Constructor Certification:

I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.

Signed [Signature] WWC Number 1592 Date 6-21-02