NOTICE TO WATER WELL CONTRACTOR  The original and first copy of this report are to be  WATER WELL	L REPORTEGEIVEU	oclar o	A
filed with the STATE OF	OREGON AUG2 3 1974state Well No. 3	25/45-20	<u> </u>
STATE ENGINEER SALEM OREGON 97310			•
within 30 days from the date of well completion.	STATE ENGINEER Permit No SALEM, OREGON	)	
(1) OWNER:	(10) LOCATION OF WELL:		
Name BIG VALLEY MOBILE HOME PARK	County CLACKAMAS Driller's well number 306		
Address 32700 S.E. LEWOOD LANE	34 34 Section 20 T. 25 R. 4E W.M.		
BORING OREGON 97009			
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision corner		
New Well Deepening Reconditioning Abandon A	,		
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w		-
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found	,3	ft.
Rotary Driven Domestic Industrial Municipal	Static level 34 ft. below land s	urface. Date 7//	8/74
Cable	Artesian pressure lbs. per square	e inch. Date	
	Til testan pressure		
CASING INSTALLED: Threaded  Welded	(12) WELL LOG: Diameter of well b	elow casing	44
8 "Diam. from + 2 ft. to 95 ft. Gage . 250"	Depth drilled 225 ft. Depth of comple		ft.
"Diam. fromft. Gage		255	
" Diam. fromft. toft. Gage	Formation: Describe color, texture, grain size a and show thickness and nature of each stratum		
	with at least one entry for each change of format	tion. Report each cha	inge in
PERFORATIONS: Perforated? Yes No.	position of Static Water Level and indicate prin	cipal water-bearing	strata.
Type of perforator used MILLS KNIFE	MATERIAL	From To	SWL
Size of perforations in. by in.	41.5		
240 perforations from 63 ft. to 93 ft.	CLAY AND GRAVEL	0 17	
perforations from ft. to ft.	RED CLAY	17 26	
perforations from ft. to ft.	CLAY GRAVEL AND		
	BOULDERS	26 31	
(7) SCREENS: Well screen installed?   Yes   No	BROWN CLAY	31 38	
Manufacturer's Name	CEMENTED GRAVEL	38 59	
Type Model No.	LOOSE GRAVEL	59 93	34
Diam. Slot size Set from ft. to ft.	BIVE CLAY	93 225	
Diem. Slot size Set from ft. to ft.			
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	HOLE BACKFILLED TO	120'	
Was a pump test made? Yes \( \sigma\) No If yes, by whom?	WITH CRUSHED ROC	K.	
Yield: 158 gal./min. with 21 ft. drawdown after 24 hrs.	CEMENT FROM 110'	TO 120°	
" " "	h Function		
	the comment of the co		
Bailer test 75 gal./min. with 8 ft. drawdown after 2 hrs.			
Artesian flow g.p.m.	"		
pperature of water 5 Depth artesian flow encountered ft.	Work started 7/5 19/4 Complete	ed 7/18	19 79
(A) CONCEDITORION	Date well drilling machine moved off of well	7/18	19 76
(9) CONSTRUCTION:	D W. Arabia O. Araba Carlotta Hama		<del></del>
Well seal—Material used	Drilling Machine Operator's Certification: This well was constructed under my		iaton
Well sealed from land surface toft.	Materials used and information reported	above are true t	to my
Diameter of well bore to bottom of seal in.	best knowledge and belief.	1/27	-3/
Diameter of well bore below seal in.	[Signed] (Drilling Machine Operator)	Date 7/2,	19
Number of sacks of cement used in well seal sacks	Drilling Machine Operator's License No.	.329	
Number of sacks of bentonite used in well seal sacks	Drining Machine Operator's Encense No.		
Brand name of bentonite	Water Well Contractor's Certification:		
Number of pounds of bentonite per 100 gallons	This well was drilled under my jurisdi	iction and this ror	ort is
of waterlbs./100 gals.	true to the best of my knowledge and bel		.O. t 18
Was a drive shoe used? Yes No Plugs Size: location ft.		ING Co.	
Did any strata contain unusable water?   Yes No	(Person, firm or corporation)	(Type or print)	n
Type of water? depth of strata	Address 6365 S.E. HILLWOO	D / MILWA	UKIE
Method of sealing strata off	Isimodi Chila	/	
Was well gravel packed? ☐ Yes ☑ No Size of gravel:	[Signed]	actor)	
Gravel placed fromft. toft.	Contractor's License No. 22 Date	7/27	19 76
Graver praced from minimum and to	HEETS IF NECESSARY)	CD#4	5656-119