NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
JUN 3 1981
WATER RESOURCES DEPT
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

CLAC C6297

State Well No. 2S/4E-27 Recondition
State Permit No.

(1) OWNER:
Name Lucien Alexander
Address 35180 SE Hi-way 211 Boring, Oreg.

(2) TYPE OF WORK (check):
New Well ☐ Deepening ☐ Reconditioning ☒ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☐
8" Diam. from 0 ft. to 250 ft. Gage .250
PVC 5" Diam. from 220 ft. to 290 ft. Gage 160#
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☒ Yes ☐ No.
Type of perforator used saw cut
Size of perforations 1/6 in. by 6 in.
90 perforations from 265 ft. to 280 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
" " "
Bailer test 10 gal./min. with 4½ ft. drawdown after 3 hrs.
Artesian flow — g.p.m. —
Temperature of water 52 Depth artesian flow encountered — ft.

(9) CONSTRUCTION:
Well seal—Material used 8" Pipe was not moved,
Well sealed from land surface to ft.
Diameter of well bore to bottom of seal in.
Diameter of well bore below seal in.
Number of sacks of cement used in well seal sacks
How was cement grout placed?
Was a drive shoe used? ☐ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☐ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☒ Yes ☐ No Size of gravel 3/8-minus
Gravel placed from 260 ft. to 290 ft.

(10) LOCATION OF WELL:
County Clackamas Driller's well number
¼ ¼ Section 27 T. 2S R. 4E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 270 ft.
Static level 228 ft. below land surface. Date
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 8"
Depth drilled — ft. Depth of completed well 290 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Removed 290'- 5" O.D. liner from 290'- 8" water well-			
gravel packed 70' 5" P.V.C. pipe N.S.F. Pipe in well- 220- 290.			
installed 1 H.P. Sub-mersible to 270'-			

Work started May 21 1981 Completed May 26 1981
Date well drilling machine moved off of well May 26 1981

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] A. O. Olsen (Drilling Machine Operator) Date May 30, 1981
Drilling Machine Operator's License No. 214

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name A. O. Olsen Well Drilling (Person, firm or corporation) (Type or print)
Address Rt 1 Box 268-B Eagle Creek, Oreg.
[Signed] A. O. Olsen (Water Well Contractor)
Contractor's License No. 284 Date May 30, 1981

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119