

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report  
are to be filed with the

WATER RESOURCES DEPARTMENT  
SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

**RECEIVED**  
MAY 11 1979  
WATER RESOURCES DEPT.  
SALEM, OREGON  
CLAC  
C6340

STATE OF OREGON  
(Please type or print)

State Well No. ZS/4E-29ac  
State Permit No. \_\_\_\_\_

(1) OWNER:

Name Thomas A. Poublon  
Address 14680 S. Redland Road, Oregon City, Ore.  
97045

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

CASING INSTALLED:

Threaded  Welded   
6" Diam. from +1 ft. to 167 ft. Gage .250  
5" Diam. from 160 ft. to 190 ft. Gage .188  
" Diam. from " ft. to " ft. Gage "

(6) PERFORATIONS:

Perforated?  Yes  No.  
Type of perforator used Mills Knife  
Size of perforations 1/8 in. by 2 in.  
180 perforations from 115 ft. to 160 ft.  
perforations from " ft. to " ft.  
perforations from " ft. to " ft.

(7) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.  
" " " " "  
" " " " "  
Baller test 35 gal./min. with 18 ft. drawdown after 1 hrs.  
Artesian flow g.p.m.  
Temperature of water 53° Depth artesian flow encountered \_\_\_\_\_ ft.

(9) CONSTRUCTION:

Well seal—Material used Cement grout  
Well sealed from land surface to \_\_\_\_\_ 22 ft.  
Diameter of well bore to bottom of seal 10 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal \_\_\_\_\_ 12 sacks  
How was cement grout placed? Pumped through a one inch pipe between the ten inch hole and the six inch casing to a depth of twenty-two feet.  
Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: 3/8  
Gravel placed from \_\_\_\_\_ 22 ft. to \_\_\_\_\_ 116 ft.

(10) LOCATION OF WELL:

County Clackamas Driller's well number 14-79  
SW 1/4 NE 1/4 Section 29 T. 2S R. 4E W.M.  
Bearing and distance from section or subdivision corner  
Eagle Creek / Howlett Road

(11) WATER LEVEL: Completed well.

Depth at which water was first found 109 ft.  
Static level 92 ft. below land surface. Date 4-28-79  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

(12) WELL LOG:

Diameter of well below casing \_\_\_\_\_  
Depth drilled 190 ft. Depth of completed well 190 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Clay; sticky, orange	0	14	
Clay; tan	14	37	
Clay; sandy, brown	37	61	
Gravel; cemented	61	104	
Clay; brown	104	109	
Gravel; loose	109	161	92
Clay; tan	161	168	
Clay; sandy, brown	168	176	
Clay; brown	176	181	
Clay; gray	181	190	

Work started 4-17- 19 79 Completed 4-28- 19 79  
Date well drilling machine moved off of well 4-28- 19 79

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Ronald F. McConnell Date April 30, 1979  
Ronald F. McConnell (Drilling Machine Operator)  
Drilling Machine Operator's License No. 398

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name Steinman Bros. Drilling Co. (Type or print)  
(Person, firm or corporation)  
Address 3023 S. E. Holly Ave., Milw., Ore. 97222  
[Signed] Ronald F. McConnell  
Ronald F. McConnell (Water Well Contractor)  
Contractor's License No. 626 Date April 30, 19 79