NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be

WATER WELL REPORT

of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date with the of well completion.

STATE ENGINEER, SALEM, OREGON 97310

Within 30 days from the date with the

		1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 -	}			
\	State	Well No.	2	4	-2	9
١.			I	-		

State Permit No.

STATE ENGINEER	(COSOO)			
(1) OWNER: SALEM OREGON	(11) LOCATION OF WELL:			
Name James Idlewine	County Clackamas Driller's well number			
Address Rt. 1 Box 228 - D Eagle Creek, Oregon	1/4 1/4 Section 29 T. 2S R. LE W.M			
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision corner			
New Well Deepening Reconditioning Abandon Life abandonment, describe material and procedure in Item 12.				
(3) TYPE OF WELL: (4) PROPOSED USE (check):				
Rotary Driven D	(12) WELL LOG: Diameter of well below casing			
Cable	Depth drilled 120 ft. Depth of completed well 118 ft			
CASING INSTALLED: Threaded Welded X 6 "Diam. from 0 ft. to 118 ft. Gage 250	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.			
" Diam. from ft. to ft. Gage	MATERIAL From To SWL			
" Diam. from ft. to ft. Gage	Sandy loam top soil 0 11			
PERFORATIONS: Perforated? Yes X No.	Large boulders sandy 11 30			
Type of perforator used				
Size of perforations in. by in.	Cemented gravel 56 118 Medium gravel sand 118 120			
perforations from ft. to ft.	medium gravel sand 118 120			
perforations fromft. toft.				
perforations from ft. to ft				
perforations from ft. to ft.				
(E) CODETING				
(7) SCREENS: Well screen installed? ☐ Yes № No				
Manufacturer's Name Model No				
Diam. Slot size Set from ft. to ft.				
Diam. Slot size Set from ft. to ft.				
(8) WATER LEVEL: Completed well.				
Seric level 100 ft. below land surface Date 7/9/68				
Arresian pressure lbs. per square inch Date				
lowered below static level				
Was a pump test made? ☐ Yes 🔂 No If yes, by whom?	Work started 6.6 ft			
d: gal./min. with tt. drawdown after hrs.	Work started 6/27/68 19 Completed 7/9/68 19			
" " " " " " " " " " " " " " " " " " " "	Date well drilling machine moved off of well 7/9/68 19			
" " " "	Drilling Machine Operator's Certification:			
Bailer test 10 gal./min. with 0ft. drawdown after 12 hrs.	This well was constructed under my direct supervision. Materials used and information reported above are true to my best			
Artesian flow g.p.m. Date	knowledge and belief			
Temperature of water 52 Was a chemical analysis made? Yes 1 No	[Signed And Machine Operator) Date 7/11/689			
(10) CONSTRUCTION:				
Well seal-Material used Gement and bentonite	Drilling Machine Operator's License No. 608			
Depth of seal	Water Well Contractor's Certification:			
Diameter of well bore to bottom of sealin.	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.			
Were any loose strata cemented off? Yes No Depth				
Did any strata contain unusable water? Yes A No	(Person, firm or corporation) (Type of print)			
Type of water? depth of strata	Address Rt. 1 Box 271 Estacada, Oregon 97023			
Method of sealing strata off	\mathcal{P}			
Was well gravel packed? ☐ Yes ♣ No Size of gravel:	[Signed] (Wyler Well Contractor)			
Gravel placed from ft. to ft.	Contractor's License No. 433 Page 8/8/69			