

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON AUG 11 1967

(Please type or print)

(Do not write above this line)

State Well No.

ENGINEER

OREGON

State Permit No.

CLAC

06361

2/4-29

(1) OWNER:

Name

Address

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:

Threaded ☐ Welded ☒

5 9/16" Diam. from 0 ft. to 21 1/4 ft. Gage 250
20" Diam. from 20 ft. to 43 ft. Gage 10
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No.

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 1 ft. below land surface Date 8/8/67

Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☐ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Bailer test 10 gal./min. with 7 ft. drawdown after 1 hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

(10) CONSTRUCTION:

Well seal—Material used Bentonite + Cement

Depth of seal 20 ft.

Diameter of well bore to bottom of seal 9 5/8 in.

Were any loose strata cemented off? ☐ Yes ☐ No Depth

Was a drive shoe used? ☒ Yes ☐ No

Did any strata contain unusable water? ☐ Yes ☐ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☐ No Size of gravel:

Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Clatsop Driller's well number

1/4 SE 1/4 Section 29 T. 25 R. 4E W.M.

Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 43 ft. Depth of completed well 43 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Gravel & Clay	0	3	
Yellow sandy clay	3	8	
Cemented gravel	8	22	
Gray silty clay	22	34	
Dark coarse black sand	34	38	
Gray clay fine gravel	38	43	

Work started Aug 2, 1967 Completed Aug 8 1967

Date well drilling machine moved off of well Aug 8 1967

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] William Nelson Date 8/8, 1967
(Drilling Machine Operator)

Drilling Machine Operator's License No. 506

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME ANDY M. JAMMER (Type or print)

Address ROUTE 1, BOX 275, ESTACADA, ORE 97023

[Signed] Andy M. Jammer (Water Well Contractor)

Contractor's License No. 412 Date Aug 8, 1967