NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

CLAC 06593

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED APR 22 1975 STATE ENGINEER SALEM, OREGON

State Well No. 25/4E-34 bc
State Permit No.

(1) OWNER:
Name John Moeller
Address 17967 S. Holly Lane
Oregon City, Ore 97045

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☑ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED: Threaded ☐ Welded ☑
6 5/8" Diam. from 0 ft. to 79 ft. Gage .250
5" Diam. from 73 ft. to 93 ft. Gage 10
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☑ Yes ☐ No.
Type of perforator used Torch
Size of perforations 3/8 in. by 12 in.
6 perforations from 80 ft. to 90 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☑ Yes ☐ No If yes, by whom? Driller
Yield: 10 gal./min. with Total ft. drawdown after 1 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 50 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Cement-bentonite-pad.clay
Well sealed from land surface to 58 ft.
Diameter of well bore to bottom of seal 9 5/8 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 2 sacks
Number of sacks of bentonite used in well seal 50 lbs sacks
Brand name of bentonite National
Number of pounds of bentonite per 100 gallons of water 1:5 ratio lbs./100 gals.
Was a drive shoe used? ☑ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Clackamas Driller's well number 757
SW ¼ NW ¼ Section 34 T. 2S R. 4E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 84 ft.
Static level 38 ft. below land surface. Date 4-12-75
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 93 ft. Depth of completed well 93 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Soil brown	0	2	
Clay brown	2	11	
Clay yellow	11	14	
Clay brown	14	18	
Claystone brown	18	37	
Consolidated Conglomerate	37	89	
Clay yellow	89	93	

Work started April 11 1975 Completed April 12 1975
Date well drilling machine moved off of well April 12 1975

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Ross Jannsen Date April 14, 1975
(Drilling Machine Operator)
Drilling Machine Operator's License No. 399

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Ross Jannsen Well Drilling
(Person, firm or corporation) (Type or print)
Address Rt. 1 Box 485 Estacada, Ore 97023
[Signed] Ross Jannsen
(Water Well Contractor)
Contractor's License No. 433 Date April 14, 1975

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45056-119