NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON, within 30 days from the date of well completion.

RECEIVED
JAN 27 1978
WATER RESOURCES DEPT.
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

CLAC C6811

State Well No. 2S/5E-17ac

State Permit No.

(1) OWNER:
Name Oral Hull Foundation % H. W. Berger
Address 38015 Jonsrud Ln., Sandy, Or. 97055

(2) TYPE OF WORK (check):
New Well [X] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary [] Driven []
Cable [X] Jetted []
Dug [] Bored []

(4) PROPOSED USE (check):
Domestic [] Industrial [] Municipal [X]
Irrigation [] Test Well [] Other []

(5) CASING INSTALLED:
Threaded [] Welded [X]
8 " Diam. from 0 ft. to 89 ft. Gage 0.250
6 " Diam. from 87 ft. to 94 ft. Gage 0.250
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:
Perforated? [X] Yes [] No
Type of perforator used Torch
Size of perforations 1/4 in. by 12 in.
18 perforations from 88 ft. to 93 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? [] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? [] Yes [X] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 50 gal./min. with 10 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 51° Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Cement
Well sealed from land surface to 24 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 35 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? [X] Yes [] No Plugs Size: location ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [X] Yes [] No Size of gravel? 3/4" minus
Gravel placed from 25 ft. to 81 ft.

(10) LOCATION OF WELL:
County Clackamas Driller's well number 1-78
SW 1/4 NE 1/4 Section 17 T. 2S R. 5E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 81 ft.
Static level 64 ft. below land surface. Date 1/13/78
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing ---
Depth drilled 96 ft. Depth of completed well 94 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Clay, brown	0	8	
Clay, boulders	8	11	
Clay, brown, granular	11	18	
Cemented gravel & boulders	18	81	
Loose gravel	81	96	64

Work started Dec. 21 1977 Completed Jan. 13 1978
Date well drilling machine moved off of well Jan. 13 1978

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Ronald F. McDonnell (Drilling Machine Operator) Date 1/18/78, 19....
Drilling Machine Operator's License No. 398

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Steinman Bros. Drilling Co. (Person, firm or corporation) (Type or print)
Address 14912 S.E. Kellogg Ave., Milwaukie, Or. 97222
[Signed] Robert E. McConnell (Water Well Contractor)
Contractor's License No. 1 Date Jan. 18, 1978

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119