

RECEIVED

CLAC
67445

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Well No. 2/6-24
State Permit No.

(1) OWNER:

Name Brightwood Water Works
Address Box 2 Brightwood, Oregon
J.A. & Frances A. Calkins

(2) LOCATION OF WELL:

County CLACKAMAS Driller's well number
1/4 1/4 Section 24 T. 2S R. 6E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other
Rotary Cable Dug
Driven Jetted Bored

(6) CASING INSTALLED:

10" Diam. from 0 ft. to 88 ft. Gage .279
Liner 8" Diam. from 86 ft. to 110 ft. Gage .277

(7) PERFORATIONS:

Perforated Yes No
Type of perforator used Torch (Liner only)
Size of perforations 3/8 in. by 8 in.
80 perforations from 88 ft. to 110 ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Cement & sand
Depth of seal 18 ft. Was a packer used? No
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 27 ft. below land surface Date 8/10/65
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? BOTTNER DRILLING CO
Yield: 100 gal./min. with 36 ft. drawdown after 4 hrs.
" 175 " 48 " 4 "
" " " " " "
Baller test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date 8/10/1965
Temperature of water 49.5° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 10"
Depth drilled 110 ft. Depth of completed well 110 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Sand, yellow	0	3
Sand & gravel	3	14
Sand, w/a little water	14	17
Sand & boulders	17	31
Boulders Sand & gravel	31	45
Boulders	45	46
Clay, yellow	46	50
Gravel, cemented	50	60
Gravel, w.brng., approx 30gpm	60	62
Rock, lava broken	62	69
Rock, loose w/ sand, no water	69	70
Gravel, cemented	70	88
Gravel and sand w/bearing	88	110

Work started 7/23/1965 Completed 8/10 1965
Date well drilling machine moved off of well 8/12 1965

(13) PUMP:

Manufacturer's Name Myers Sub. Cat. No. SC1500AA6
Type: Submersible Serial C 3008, 15

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME HAAKON BOTTNER DRILLING COMPANY
(Person, firm or corporation) (Type or print)
Address 3424 S.E. 174th. AVE. Portland Oregon

Drilling Machine Operator's License No. 246

[Signed] Haakon Bottner
(Water Well Contractor)

Contractor's License No. 109 Date Sept. 21 1965