

RECEIVED

JUN 12 1984

25/6E-26 ad

STATE OF OREGON WATER WELL REPORT (as required by ORS 537.765)

CLAC 07486

PLEASE TYPE OR PRINT IN INK WATER RESOURCES DEPT SALEM, OREGON

(for official use only)

(1) OWNER:

Name COUNTRY CLUB WATER DISTRICT Address P.O. BOX 168 City BRIGHTWOOD State OREGON

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air [X] Driven [] Rotary Mud [] Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [X] Thermal: Irrigation [] Withdrawal [] ReInjection [] Other: Piezometric [] Grounding [] Test []

(5) CASING INSTALLED:

6" Diam. from +2 ft. to 58 ft. Gauge .250 Steel [X] Threaded [] Plastic [] Welded [X]

LINER INSTALLED:

4" Diam. from +2 ft. to 280 ft. Gauge 160# PVC Steel [] Threaded [] Plastic [X] Welded [X]

(6) PERFORATIONS:

Size of perforations 1/8 in. by Perforated? [X] Yes [] No 2 in. 240 perforations from 240 ft. to 275 ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Type Model No. Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [X] No If yes, by whom? Air Test 23 gpm w/drill stem @ 262' 1" Air test 20 gal./min. with drill stem at 212 ft. 1 hrs. Bailer test Artesian flow g.p.m. Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes [] No [X] Well seal—Material used Cement w/5% Bentonite Well sealed from land surface to 30 ft. Diameter of well bore to bottom of seal 10 in. Diameter of well bore below seal 6 in. Amount of sealing material 12 sacks [X] pounds [] How was cement grout placed? Pumped

Was pump installed? NO Type HP Depth ft. Was a drive shoe used? [X] Yes [] No Plugs Size: location ft. Did any strata contain unusable water? [] Yes [X] No. Type of Water? depth of strata Method of sealing strata off Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft.

(10) LOCATION OF WELL by legal description:

County Clackamas SE 1/4 NE 1/4 of Section 26 of Township 2 South Range 6 East WM. (Township is North or South) (Range is East or West) Tax Lot Lot Block Subdivision MAILING ADDRESS OF WELL (or nearest address) P.O. BOX 168, Brightwood, Oregon 97011

(11) WATER LEVEL of COMPLETED WELL:

Depth at which water was first found 66 ft. Static level 120 ft. below land surface. Date 6-5-84 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing -0- Depth drilled 282 ft. Depth of completed well 280 ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include Soil, Clay, brown, Clay, brown & boulders, Basalt, broken, Basalt, black, Basalt, black broken, Basalt, black, Basalt, red, Basalt, black, Basalt, black, crevised, Basalt, black, softer, Basalt, grey, Basalt, black, Basalt, black, fractured, Basalt, black.

Date work started 5-29-84 /completed 6-5-84 Date well drilling machine moved off of well 6-5 19 84

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Date, 19

(bonded) Water Well Constructor Certification:

Bond 94-97-459 Issued by: Fidelity & Deposit Co (number) (Surety Company Name) On behalf of Marvin D. Skyles (SKYLES DRILLING) (type or print name of Water Well Constructor)

License #553 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:

(Signed) Marvin D Skyles (Water Well Constructor) (Dated) 05 June 1984

NOTICE TO WATER WELL CONSTRUCTOR The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*46866-690