

WATER WELL REPORT
STATE OF OREGON

CLAC
07578

RECEIVED

APR 29 1983

State Well No. 25/7E-300A

25/7E-300A

PLEASE TYPE OR **WATER RESOURCES DEPT.**
SALEM, OREGON

State Permit No.

(1) OWNER:

Name Timberline Rim Recreation Club
Address Box 206
City Brightwood, Oregon State 97011

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven Domestic Industrial Municipal
Rotary Mud Dug Irrigation Test Well Other
 Bored Thermal: Withdrawal Reinjection

(4) PROPOSED USE (check):

(5) CASING INSTALLED:

Steel Plastic
Threaded Welded

8" Diam. from + 1 1/2 ft. to 125 1/2 ft. Gauge .250
6" Diam. from 120 ft. to 130 ft. Gauge .188
150 ft. to 170 ft. Gauge .250

LINER INSTALLED:

" Diam. from ft. to ft. Gauge

(6) PERFORATIONS:

Perforated? Yes No

Type of perforator used

Size of perforations in by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name U.O.P. Johnson
Type Stainless Steel Model No.
Diam. 8 Slot Size 050 Set from 130 ft. to 150 ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? A.M. Janssen
Flow: 370 gal/min. with 15 ft. drawdown after 12 hrs.
Air test gal./min. with drill stem at ft. hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow 150 g.p.m.
Temperature of water 49° Depth artesian flow encountered 127 ft.

(9) CONSTRUCTION:

Special standards: Yes No

Well seal—Material used Cement grout + 5% gel
Well sealed from land surface to 125 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 49 sacks
How was cement grout placed? 49 sacks pumped to bottom & back to surface
Was pump installed? no Type HP Depth ft.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel: ft.
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Clackamas Driller's well number
NE 1/4 SW 1/4 Section 30 T. 2 S R. 7 E. W.M.
Tax Lot # Lot Blk Subdivision
Address at well location:

(11) WATER LEVEL: Completed well.

Depth at which water was first found 127 ft.
Static level ft. below land surface. Date
Artesian pressure 3 lbs. per square inch. Date 4/20/83

(12) WELL LOG:

Diameter of well below casing

Depth drilled 195 ft. Depth of completed well 170 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Topsoil	0	1	
Boulders, cobble & sand	1	25	
Cobbles w/gravels & sand. Occ. boulder	25	53	
Slightly cemented sand & gravel --occ. boulder	53	87	
Conglomerate - sands, med. gravel w/ light gray sandy clay	87	94	
Conglomerate - sand, med. gravels w/dark brown clay	94	117	
Med. gravels w/fine gray sand	117	125	
Gray clay	125	127	
Fine to coarse gray sand w/ fine to med. gravels	127	176	
Fine to coarse gray sand	176	195	
Well completed to 170 ft.			

Work started 3/10 1983 Completed 4/20 1983
Date well drilling machine moved off of well 4/20/83 19

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] A.M. Janssen Date 4/27, 1983

Bonded Water Well Constructor Certification:

Bond (number) Issued by: Great American Insurance
Surety Company Name
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name A.M. JANSSEN WELL DRILLING CO., INC.
(Person, firm or corporation) (Type or print)
Address 21075 SW Tualatin Valley Hwy. Aloha, Oregon
[Signed] A.M. Janssen Water Well Constructor
Date 4/25, 1983.