

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED WATER WELL REPORT

CLAC 7600

DEC 2 - 1971

STATE OF OREGON

State Well No. 2/7-32

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date

STATE ENGINEER

(Please type or print)

State Permit No.

SALEM, OREGON (Do not write above this line)

(1) OWNER:

Name Mrs. Jeanne Thurman
Address 8509 N. E. Multnomah Portland, Oregon

(2) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [x] Driven []
Cable [] Jetted []
Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [x] Industrial [] Municipal []
Irrigation [] Test Well [] Other []

(5) CASING INSTALLED:

Threaded [] Welded [x]
8" Diam. from 0 ft. to 94 ft. Gage 1/4 wall

PERFORATIONS:

Perforated? [] Yes [x] No

Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [] Yes [x] No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [] Yes [x] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
50 gal./min. with 55 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Bentonite
Well sealed from land surface to 30 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal sacks
Number of sacks of bentonite used in well seal 2 Bentonite sacks
Brand name of bentonite National
Number of pounds of bentonite per 100 gallons of water 50 lbs./100 gals.
Was a drive shoe used? [] Yes [x] No Plugs Size: location ft.
Did any strata contain unusable water? [] Yes [x] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [] Yes [x] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Clackamas Driller's well number
1/4 1/4 Section 32 T. 2-S R. 7-E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 15 ft.
Static level 30 ft. below land surface. Date 11-19-71
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8
Depth drilled 105 ft. Depth of completed well 105 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include: Top soil, Yellow sandy clay, yellow clay sand and boulders, Gray glacial rock.

Work started 11-15-71 19 Completed 11-19-71 19
Date well drilling machine moved off of well 11-19-71 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Ralph Turner Date 11-29-71 19
(Drilling Machine Operator)
Drilling Machine Operator's License No. 254

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Ralph Turner Drilling Co. (Type or print)
Address Rte. 1, Box 141, Hillsboro, Oregon
[Signed] Ralph Turner (Water Well Contractor)
Contractor's License No. 247 Date 11-29-71 19